

**NORTHERN REGION
IDWR**

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter
or
Ball Point Pen

1. DRILLING PERMIT NO. 95-95-N-150-000
Other IDWB No. _____

2. OWNER:


2. OWNER:
Name **JOE ANDREWS**

Address **NONE**

City **Coeur d'Alene** State **ID** Zip **83814**

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.



Twp. 50N North ☐ or South ☒
 Rge. 4W East ☐ or West ☒
 Sec. 34
 Gov't Lot _____ County Neotoma ^{10 acres} 1/4 ^{160 acres} 1/4

Address of Well Site **PRESLEY RD.**

Address of Well Site **PRESLEY RD.**

(Give at least name of road + Distance to Road or Landmark)

Lt.	Blk.	Sub. Name
-----	------	-----------

4. PROPOSED USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK

☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD

☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0"	210"	42 SA	DRY

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s) _____
Was drive shoe seal tested? Y ☐ N ☒ - How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+1"	210"	.250	STEEL	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations Method _____

☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

210 ft. below ground Artesian pressure 1 lb.
Depth flow encountered 1 ft. Describe access port or
control devices: CAP.

NWSW 34 SON 4w

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
5EST	100%	396'	21/24R

Water Temp. _____ Bottom hole temp. _____

Water Quality test or comments:

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

[illegible]

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name **United Drilling In .** Firm No. **414**

Firm Official [Signature] Date 8/30/95

and
Supervisor or Operator **LARRY VANDERLINDEN** Date **8/30/95**

(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES