

HEDGE PIN 0-7165-000-003-0



IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT
RECEIVED

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat	:	Long
:	:	:

1. WELL TAG NO. D0033475 JAN 30 2004
DRILLING PERMIT NO 810182 IDWR/North
Other IDWR No. _____

2. OWNER:
Name Debbie Johnson
Address 7305 Crenshaw
City Rathdrum State _____ Zip 83858

3. LOCATION OF WELL by legal description:
N Twp 51N North ☒ or South ☐
Rge 05W East ☐ or West ☒
Sec 23 1/4 SW 1/4 SW 1/4
10 Ac 40 Ac 160 Ac
Gov't Lot _____ County Kootenai
Lat _____ Long _____
S
Address of Well Site: (see next line)
City _____
Raging Bull Lane Well #2 _____
Lot _____ Blk _____ Sub. Name (see next line) _____

4. USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)
☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD
☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite Grans	0	18	8 sacks	Pour in

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) _____ Ring Bit 303
Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	2	303	0.250	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length Headpipe _____ Length Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations? Method Air Perforator
☐ Screens? Screen Type _____

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
280	300	1x1/4	200	6	Steel	☒	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

248 ft. below ground. Artesian pressure _____ lb.
Depth flow encountered 248 ft. Describe access port or control devices: Steel Cap Welded

51N 5W 23

11. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
20	100%	300	1 Hour

Water Temp. _____ Cold _____ Bottom hole temp. _____ Cold _____
Water Quality test or comments: (below) Depth first Water Encountered 248
Cold, Clear, and No Smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
8	0	2	Topsoil	☐ Y	☒ N
8	2	110	Sand and Gravel 3/4 inch Minus	☐ Y	☒ N
8	110	147	Sand and Gravel 1 inch Minus	☐ Y	☒ N
8	147	303	Sand and Gravel 3/4 inch Minus	☒ Y	☐ N

Completed Depth 303 (Measurable)
Date: Started 1/12/04 Completed 1/15/04

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc. Firm No 414
Firm Official Tim M. Valters Date 1/15/04
Supervisor or Operator Jason C. Beckham Date 1/15/04