

WELL DRILLER'S REPORT

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat:	Long:	

1. WELL TAG NO. D0054442

Drilling Permit No:
Other IDWR No.

850914

2. OWNER

Name RYEN, CAL

Address 1904 CHERYL COURT

City SPOKANE State WA Zip 99037

Well Number:
1404

3. LOCATION OF WELL by legal description

sketch map location must agree with written location

N		Twp. 50N		✓	North or	South
W		Rge. 04W			East or	✓ West
E		Sec. 07			1/4 NE	1/4 SE 1/4
		Gov't Lot		County KOOTENAI		
		Latitude:		Longitude		

Address of Well Site 6513 W. Harbor Dr.

City POST FALLS

(Give at least name of road + Distance to Road or Landmark)

Lt. 8 Blk. Sub. Name

4. USE:

✓ Domestic Municipal Monitor Irrigation
Thermal Injection Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

✓ New Well Modify Abandonment Other

6. DRILL METHOD

✓ Air Rotary Cable Mud Rotary Other

7. SEALING PROCEDURES

SEAL/FILTER PACK	AMOUNT	METHOD
Material From To Sacks or Pounds		
BENTONITE 0 18 600 LBS	OVERBORE	

Was drive shoe used? Y ✓ N Shoe Depth(s) RB

Was drive shoe seal tested? Y ✓ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	201	.250	STEEL	✓		✓	
5	-197	213	.250	STEEL	✓		✓	

Length of Headpipe 5 Length of Tailpipe

9. PERFORATIONS/SCREENS

Perforations Method
✓ Screens Screen Type JOHNSON SS

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
203	213	.10	2	5	SS		

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

170 ft. below ground Artesian pressure lb.
Depth flow encountered 185 ft. Describe access port or control devices:

SON 04W 07

11. WELL TESTS:

Pump	Bailer	✓ Air	Flowing Artesian
Yield gal./min.	Drawdown	Pumping Level	Time
10			1 HR.

Water Temp. COL Bottom Hole Temp COLD

Water Quality test or comments: GOOD

Depth first Water encountered 185

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Base Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water
10	0	3	Top Soil	✓
10	3	18	Sand, Clay, Gravels	✓
8	18	90	Small Gravels & Sand	✓
8	90	120	Black Med. Basalt	✓
8	120	190	Fine Sand	✓
8	190	220	Coarse Sand	✓

RECEIVED

APR 24 2009

IDWR / NORTH

Completed Depth 213	(Measurable)
Date: Started 3/27/2008	Completed 3/31/2008

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O Well Service, Inc. Firm No. 448

Firm Official *Jim McLeslie* Date

and Supervisor or Operator *Jim McLeslie* Date 3/31/2008
JIM MCLESLIE (Sign Once if Firm Official and Operator)