

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat	Long	

1. WELL TAG NO. D0039880

Drilling Permit No: 830190

Other IDWR No.

2. OWNER

Name Stippich, Jason

Well Number:


917

Address 3800 Highwater Dr

City Post Falls State ID Zip 83854

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 52 ☒ North or ☐ South

Rge. 4 ☐ East or ☒ West

Sec. 15 SW 1/4 SW 1/4 1/4

Gov't Lot County KOOTENAI

Lat. : : Long: : :

Address of Well Site Chrissan Ct

City Rathdrum

(Give at least name of road + Distance to Road or Landmark)

Lt. 8 Blk. 2 Sub. Name Weller Estates

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	20	700lbs	Overbore

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s) RB

Was drive shoe seal tested? ☐ Y ☒ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	360	.250	Steel	☒	☐	☒	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations Method Down Hole

☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
345	360	1/4 x 2	240	6	Steel	☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

300 ft. below ground Artesian pressure lb.

Depth flow encountered 300 ft. Describe access port or

control devices: Welded Cap

11. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
40+			2hrs

Water Temp. Cold Bottom Hole Temp Cold

Water Quality test or comments: Good, Little clo

Depth first Water encountered 300

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

				Water	
Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Y	N
10	0	12	Soil w/ cobble & granite	☐	☒
10	12	18	Soil w/ cobble & granite	☐	☒
8	18	131	Sand & Gravel 3-4 minus	☐	☒
8	131	155	Sand Course	☐	☒
8	155	300	Sand & Gravel Course 3-4 minus w/ cob	☐	☒
8	300	305	Boulders	☐	☒
8	305	360	Sand & Gravel w/ water apx 40 + gpm	☒	☐

RECEIVED
MAR 14 2005
IDWR/North

Completed Depth 360 (Measurable)

Date: Started 2/28/2005 Completed 3/1/2005

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official Date 3-3-05

and
Supervisor or Operator Date 03/01/05

Louie Hanner

(Sign Once if Firm Official and Operator)

52N 4W 15

STIPPICH PIN 0-8535-002-008-0

