USE TYPEWRITER OR BALL POINT PEN

State of Idaho
Department of Water Resources

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

RECEIVED

1. WELL OWNER

Name Don Usher

Address S. 1303 Ray Spokane, wa. 99202

Owner's Permit No. 95-76-N-108

2. NATURE OF WORK

☑ New well ☐ Deepened ☐ Replacement

☐ Abandoned (describe method of abandoning)

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type)

☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

4. METHOD DRILLED

☐ Cable ☒ Rotory ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 63 feet

Casing schedule: ☒ Steel ☐ Concrete

Thickness	Diameter	From	To
____ inches	6 inches	+ 3'3" feet	44'7" feet
____ inches	____ inches	____ feet	____ feet
____ inches	____ inches	____ feet	____ feet
____ inches	____ inches	____ feet	____ feet
____ inches	____ inches	____ feet	____ feet

Was casing drive shoe used? ☒ Yes ☐ No

Was a packer or seal used? ☐ Yes ☒ No

Perforated? ☐ Yes ☒ No

How perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation ____ inches by ____ inches

Number		From	To
____	perforations	____ feet	____ feet
____	perforations	____ feet	____ feet
____	perforations	____ feet	____ feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name ____

Type ____ Model No. ____

Diameter ____ Slot size ____ Set from ____ feet to ____ feet

Diameter ____ Slot size ____ Set from ____ feet to ____ feet

Gravel packed? ☐ Yes ☑ No Size of gravel ____

Placed from ____ feet to ____ feet

Surface seal depth 20 Material used in seal ☐ Cement grout ☒ Puddling clay ☐ Well cuttings

Seating procedure used ☐ Slurry pit ☐ Temporary surface casing ☒ Overbore to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name ____

Lot No. ____ Block No. ____

County Kootenai

SE ¼ NE ¼ Sec. 7, T. 50 N/S, R. 4 E/W

7. WATER LEVEL

Static water level ____ feet below land surface

Flowing? ☐ Yes ☐ No G.P.M. flow ____

Temperature ____ ° F. Quality ____

Artesian closed-in pressure ____ p.s.i.

Controlled by ☐ Valve ☐ Cap ☐ Plug

8. WELL TEST DATA

☐ Pump ☐ Bailer ☒ Other

Discharge G.P.M.	Draw Down	Hours Pumped
10		

9. LITHOLOGIC LOG

Hole Diam.	Depth From	Depth To	Material	Water Yes	Water No
6	0	1	top soil		
	1	48	dirty sand and gravel		
	48	63	basalt		
			57' of 4" PVC		
			20' perforated		
			60 perforations 1/2 x 6"		

10.

Work started 5/31/76 finished 6/1/76

11. DRILLERS CERTIFICATION

Firm Name Bartholomew Drilling Firm No. 52

Address Nine Mile Falls, Wa. 9902 Date 6/23/76

Signed by (Firm Official) W. E. Bartholomew

and

(Operator) Lynn [illegible]

USE ADDITIONAL SHEETS IF NECESSARY FORWARD THE WHITE COPY TO THE DEPARTMENT