

REWRITE FOR
ALL POINT PEN

State of Idaho
Department of Water Administration

ENTD

RECEIVED

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Administration, within 30 days after the completion or abandonment of the well.

6/9/09 -

WELL WAS
GRAVEL PACKED
TO HOLD BACK
SAND -
DATE OF WELL
MOD. 1990

RICHIE
UNITED CROWN
Jen

1. WELL OWNER

Name Careville Corp. Inc.

Address Box 771 Coeur d'Alene, Idaho

Owner's Permit No. 95-74-N-75

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement

☐ Abandoned (Describe method of abandoning)

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Other (Specify type)

☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

4. METHOD DRILLED

☒ Cable ☐ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 8 inches Total depth 351 feet

Casing schedule: ☒ Steel ☐ Concrete

Thickness	Diameter	From	To
<u>250</u> inches	<u>8</u> inches	<u>0</u> feet	<u>351</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was a packer or seal used? ☐ Yes ☒ No

Perforated? ☒ Yes ☐ No

How perforated? ☒ Factory ☐ Knife ☐ Torch

Size of perforation 3/8 inches by 2 inches

Number	From	To
<u>80</u> perforations	<u>328</u> feet	<u>346</u> feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name _____

Type _____ Model No. _____

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes ☒ No Size of gravel _____

Placed from _____ feet to _____ feet

Surface seal depth 18 Material used in seal ☐ Cement grout


☒ Pudding clay ☐ Well cuttings

Sealing procedure used ☐ Sherry pit ☒ Temporary surface casing

☐ Overbars to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name _____

Lot No. _____ Block No. _____

County Kootenai

NW 1/4 SE 1/4 Sec. 22 T. 51 N/S, R. 4 E/W P.M.

7. WATER LEVEL

Static water level _____ feet below land surface

Flowing? ☒ Yes ☐ No G.P.M. flow 15

Temperature _____ ° F. Quality _____

Artesian closed-in pressure _____ p.s.i.

Controlled by ☐ Valve ☐ Cap ☐ Plug

8. WELL TEST DATA

☒ Pump ☐ Bailor ☐ Other

Discharge G.P.M.	Draw Down	Hours Pumped
<u>15</u>	<u>total</u>	<u>2</u>

9. LITHOLOGIC LOG

Hole Diam.	Depth		Material	Water Yes/No
	From	To		
<u>8</u>	<u>0</u>	<u>4</u>	<u>surface soil</u>	
	<u>4</u>	<u>185</u>	<u>sand small gravel</u>	
	<u>185</u>	<u>280</u>	<u>sand large gravel</u>	
	<u>280</u>	<u>285</u>	<u>sand large gravel gravel boulders</u>	
	<u>285</u>	<u>300</u>	<u>sand small gravel</u>	<u>x some</u>
	<u>300</u>	<u>351</u>	<u>sand pea gravel</u>	<u>x</u>

10.

Work started April 12, 1974 finished April 30, 1974

11. DRILLERS CERTIFICATION

Firm Name Siler Equipment Sales, Inc. Firm No. 244

Address Box 565 Kellogg, Idaho Date 5/23/74

Signed by (Firm Official) Earl T. Siler

and
Operator London Pardo

95-8115

SCANNED

SEP - 8 2009

USE ADDITIONAL SHEETS IF NECESSARY

FORWARD THE WHITE COPY TO THE DEPARTMENT