Form 238-7
8/95

RECEIVED
AUG 27 1997
NORTHERN REGION

IDAHO DEPARTMENT OF WATER RESOURCES

Starshine Consulting and Management Services

WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

097078

Office Use Only
Inspected by TOK
Twp SE 1/4 Rge NE 1/4 Sec NW 1/4
Lat: : : Long: : :

1. DRILLING PERMIT NO. TAG#D0003228
Other IDWR No. IDWR 95.97.10.93

2. OWNER **Well Number:** 589
Name SCARCELLO, PEGGY
Address 22025 N KEVIN RD
City RATHDRUM State ID Zip 83858

3. LOCATION OF WELL by legal description
sketch map location must agree with written location

N
X
S

Twp. 52 ☑ North or ☐ South
Rge. 04 ☐ East or ☑ West
Sec. 09 1/4 NE 1/4 NW 1/4
Gov't Lot County KOOTENAI
Lat: : : Long: : :
Address of Well Site SAME AS ABOVE
City RATHDRUM
(Give at least name of road + Distance to Road or Landmark)
Blk. Sub. Name

4. USE:
☑ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)
☑ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD
☑ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
BENTONITE	0	18	6 BAGS	POUR DRY

Was drive shoe used? ☐ Y ☐ N Shoe Depth(s)
Was drive shoe seal tested? ☐ Y ☐ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+1	400	.250	STEEL	☑	☐	☑	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS
☐ Perforations Method
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
350 ft. below ground Artesian pressure lb.
Depth flow encountered ft. Describe access port or control devices:

NENW 9 52N 4W

11. WELL TESTS:
☐ Pump ☐ Bailer ☑ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
15+		395	1 HR

Water Temp. COLD Bottom Hole Temp
Water Quality test or comments: CLEAR
Depth first Water encountered

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water Y	Water N
8	0	1	TOPSOIL	☐	☑
8	1	124	Gravels W/Sand	☐	☑
8	124	340	Coarse Sand	☐	☑
8	340	400	Gravels W/Sand	☑	☐

Completed Depth 400' (Measurable)
Date: Started 8/21/97 Completed 8/22/97

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H20 WellService, Inc. Firm No. 448
Firm Official Date 8/22/97
and
Supervisor or Operator Date 8/22/97
(Sign Once if Firm Official and Operator)

(Todd Morgan)