GERRY-SMITH FAMILY TRUST PIN 52N03W-30-2500

USE TYPEWRITER OR BALL POINT PEN

State of Idaho
Department of Water Administration

WELL DRILLER'S REPORT

1465

ENT'D

State law requires that this report be filed with the Director, Department of Water Administration within 30 days after the completion or abandonment of the well.

1. WELL OWNER

Name Warren Nichols

Address Garwood road Hayden Lake, Idaho

Owner's Permit No. 95-78-N-4

2. NATURE OF WORK

XX ☐ New well ☐ Deepened ☐ Replacement

☐ Abandoned (describe method of abandoning)

3. PROPOSED USE

XX ☐ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type)

☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

4. METHOD DRILLED

☐ Cable XX Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6" inches Total depth 260' feet

Casing schedule: XX Steel ☐ Concrete

Thickness	Diameter	From	To
.250 inches	6" inches	+1 feet	18' feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was a packer or seal used? ☐ Yes XX No

Perforated? ☐ Yes XX No

How perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation _____ inches by _____ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes XX No

Manufacturer's name _____

Type _____ Model No. _____

Diameter ___ Slot size ___ Set from _____ feet to _____ feet

Diameter ___ Slot size ___ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes XX No Size of gravel _____

Placed from _____ feet to _____ feet

Surface seal depth 18' Material used in seal ☐ Cement grout XX Puddling clay ☐ Well cuttings

Sealing procedure used ☐ Slurry pit ☐ Temporary surface casing XX Overbore to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name _____

Lot No. _____ Block No. _____

County Kootenai

NW ¼ NE ¼ Sec. 30, T. 52N N/S, R. 3W E/W

7. WATER LEVEL

Static water level none feet below land surface

Flowing? ☐ Yes ☐ No G.P.M. flow none

Temperature _____ ° F. Quality _____

Artesian closed-in pressure _____ p.s.i.

Controlled by ☐ Valve ☐ Cap ☐ Plug

8. WELL TEST DATA

☐ Pump ☐ Bailer ☐ Other

Discharge G.P.M.	Draw Down	Hours Pumped

9. LITHOLOGIC LOG

Hole Diam.	Depth From	Depth To	Material	Water Yes	Water No
6"	-	03	topsoil		X
	03	10	large gravel & boulders		X
	10	18	gravel		X
	18	172	hard black basalt		X
	172	190	black ash & cinders		X
	190	210	brown clay		X
	210	214	black basalt		X
	214	260	brown clay		X

RECEIVED
FEB 8 1982
Department of Water Resources

10.

Work started 6-30-78 finished 7-4-78

11. DRILLERS CERTIFICATION

Firm Name FINDLAY DRILL Firm No. 62

Address Box 386 Hayden Lake, Idaho Date 7-8-78

Signed by (Firm Official) Bill E Findlay

and

(Operator) Burl Findlay

USE ADDITIONAL SHEETS IF NECESSARY FORWARD THE WHITE COPY TO THE DEPARTMENT

MICROFILMED