

MILNER PIN 51N04W-26-4025



STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORTUSE TYPEWRITER OR
BALLPOINT PENState law requires that this report be filed with the Director, Department of Water Resources
within 30 days after the completion or abandonment of the well.

APR 21 1983

1. WELL OWNER

Name Alan R. Eborall
Address 3655 N. GOVERNMENT WAY CDA, ID
Owner's Permit No. 95-83-N-97

7. WATER LEVEL

Static water level 270 feet below land surface.
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Artesian closed-in pressure _____ p.s.i.
Controlled by: ☐ Valve ☒ Cap ☐ Plug
Temperature Cold OF. Quality Good

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning) _____

8. WELL TEST DATA

☐ Pump ☐ Bailer ☐ Air ☐ Other _____

Discharge G.P.M.	Pumping Level	Hours Pumped
<u>40</u>		<u>1.5</u>

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal
☐ Industrial ☐ Stock ☐ Waste Disposal or Injection
☐ Other _____ (specify type)

4. METHOD DRILLED

☒ Rotary ☐ Air ☐ Hydraulic ☐ Reverse rotary
☐ Cable ☐ Dug ☐ Other _____

5. WELL CONSTRUCTION

Casing schedule: ☒ Steel ☐ Concrete ☐ Other _____

Thickness	Diameter	From	To
<u>2.50</u> inches	<u>8</u> inches	<u>2</u> feet	<u>316</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was casing drive shoe used? ☒ Yes ☐ NoWas a packer or seal used? ☐ Yes ☒ NoPerforated? ☐ Yes ☒ NoHow perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation _____ inches by _____ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name _____

Type _____ Model No. _____

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes ☒ No Size of gravel _____

Placed from _____ feet to _____ feet

Surface seal depth 20 Material used in seal: ☐ Cement grout☒ Puddling clay ☒ Well cuttingsSealing procedure used: ☐ Slurry pit ☒ Temp. surface casing☒ Overbore to seal depthMethod of joining casing: ☐ Threaded ☒ Welded ☐ Solvent

Weld

☐ Cemented between strata


Describe access port _____

10.

Work started 2/21/83 finished 3/1/83

6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name _____

Lot No. _____ Block No. _____

County Kootenai

SW 1/4 NW 1/4 Sec. 26, T. 51 N., R. 4 E.

11. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were
compiled with at the time the rig was removed.Associated well
Firm Name Dillon's Inc Firm No. 245Address Box 723 CDA Date 3/1/83Signed by (Firm Official) Bob Thorntonand
(Operator) Robert J. Degey