

REPORT OF WELL DRILLER
State of Idaho



State law requires that this report shall be filed with the State Reclamation Engineer within 30 days after completion or abandonment of the well.

WELL OWNER:

Name DAYTON WEST

Address PLUMMER IDAHO

93-66-N-3

Owner's Permit No. _____

NATURE OF WORK (check): Replacement well ☐

New well ☒ Deepened ☐ Abandoned ☐

Water is to be used for: LIVESTOCK

METHOD OF CONSTRUCTION: Rotary ☐ Cable ☒

Dug ☐ Other _____

(explain) _____

CASING SCHEDULE: Threaded _____ Welded ☒

6 "Diam. from 0 ft. to 110 ft.

"Diam. from _____ ft. to _____ ft.

"Diam. from _____ ft. to _____ ft.

"Diam. from _____ ft. to _____ ft.

Thickness of casing: 1/4 in Material: _____

Steel ☒ concrete ☐ wood ☐ other ☐

(explain) _____

PERFORATED? Yes ☐ No ☒ Type of perforator used: _____

Size of perforations: _____ " by _____ "

perforations from _____ ft. to _____ ft.

perforations from _____ ft. to _____ ft.

perforations from _____ ft. to _____ ft.

perforations from _____ ft. to _____ ft.

WAS SCREEN INSTALLED? Yes ☐ No ☒

Manufacturer's name _____

Type _____ Model No. _____

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

CONSTRUCTION: Well gravel packed? Yes ☐

No. ☒ size of gravel _____ Gravel

placed from _____ ft. to _____ ft. Surface seal

provided? Yes ☐ No ☐ To what depth?

_____ ft. Material used in seal: _____

Did any strata contain unusable water? Yes ☐

No. ☒ Type of water: _____

Depth of strata _____ ft. Method of sealing

strata off: _____

Surface casing used? Yes ☐ No ☐

Cemented in place? Yes ☐ No ☐

Locate well in section

LOCATION OF WELL: County BENENAH
S4 SE 1/4 Sec. 34 T. 46 N/S R. 5 W

Size of drilled hole: 6 1/2 Total
depth of well: 222 Standing water
level below ground: 164 Temp.
Fahr. _____ ° Test delivery: 15 gpm
or _____ cfs Pump? ☒ Bail ☐
Size of pump and motor used to make test: _____

Length of time of test: 2 Hrs. _____ Min.

Drawdown: 164 ft. Artesian pressure: ft.

above land surface _____ Give flow _____ cfs

or _____ gpm. Shutoff pressure: _____

Controlled by: Valve ☐ Cap ☐ Plug ☐

No control ☐ Does well leak around casing?

Yes ☐ No ☒

DEPTH	MATERIAL	WATER
FROM	TO	YES OR NO

0	70	CLAY	
70	70	IRON OXIDE PAN LAYER	
70	80	HUMUS ORGANIC PEAT SOIL	
80	90	PODZOLIC FOREST SOIL	
90	109	BLUE FIRE CLAY	
109	115	SAND FILTER ZONAL SOIL	
115	150	PODZOL CLAY BLACK GRANITE	
		WITH BASALT	
150	205	BLACK GRANITE WITH BASALT	
205	222	DARK BASALT WATER BEARING	YES

Work started: NOV 4 - 1966

Work finished: DEC. 16 - 1966

Well Driller's Statement: This well was drilled under my supervision and this report is true to the best of my knowledge.

Name: WILMET FREDERICK

Address: SPIRIT LAKE IDAHO

Signed by: Wilmet Frederick

License No. 317 Date: 12-29-66

Use other side for additional remarks