

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30
days after the completion or abandonment of the well.

RECEIVED

APR 21 1977

1. WELL OWNER

Name EARL SmithAddress Est 9319 Valleyway
SPOKANE, WashingtonOwner's Permit No. 5 99006

7. WATER LEVEL

Static water level 180 feet Department of Water ResourcesFlowing? ☐ Yes ☒ No G.P.M. flowTemperature Cold F. Quality

Artesian closed-in pressure p.s.i.

Controlled by ☐ Valve ☐ Cap ☐ Plug2. NATURE OF WORK 95-77-N-87☒ New well ☐ Deepened ☐ Replacement☐ Abandoned (describe method of abandoning)

8. WELL TEST DATA

☐ Pump ☐ Bailor ☒ Other AIR

Discharge G.P.M. Draw Down Hours Pumped

15 + GPM

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type)☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or
Injection

4. METHOD DRILLED

☐ Cable ☒ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 390 feetCasing schedule: ☒ Steel ☐ Concrete

Thickness Diameter From To

3.50 inches 6 inches + 1 feet 140 1/4 feet

inches inches feet feet

inches inches feet feet

inches inches feet feet

inches inches feet feet

Was casing drive shoe used? ☒ Yes ☐ NoWas a packer or seal used? ☐ Yes ☒ NoPerforated? ☐ Yes ☒ NoHow perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation inches by inches

Number From To

perforations feet feet

perforations feet feet

perforations feet feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name

Type Model No.

Diameter Slot size Set from feet to feet


Diameter Slot size Set from feet to feet

Gravel packed? ☐ Yes ☒ No Size of gravel

Placed from feet to feet

Surface seal depth 18 Material used in seal ☐ Cement grout☒ Pudding clay ☐ Well cuttingsSealing procedure used ☐ Slurry pit ☐ Temporary surface casing☒ Overbore to seal depth6. LOCATION OF WELL 95

Sketch map location must agree with written location.



Subdivision Name

Lot No. Block No.

County KOOTENAISE 1/4 Sec. 24, T. 51 N., R. 6 W.

10.

Work started 3/25/77 finished 4/16/77

11. DRILLER'S CERTIFICATION

Firm Name AMERICAN DRILLING Firm No. 269Address 3423 N. Sullivan Rd. Date 4/18/77P.O. Box 141977 SPOKANE, WASH. IDSigned by (Firm Official) [Signature]

and

(Operator) [Signature]

USE ADDITIONAL SHEETS IF NECESSARY

FORWARD THE WHITE COPY TO THE DEPARTMENT