

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

Office Use Only		
Inspected by _____		
Twp _____	Rge _____	Sec _____
1/4 _____	1/4 _____	1/4 _____
Lat: : : _____	Long: : : _____	

1. WELL TAG NO. D0003918

DRILLING PERMIT N _____

Other IDWR No _____

2. OWNER:

Name Albert Bolich

Address Greens Ferry Bridge RD

City Post Falls State ID Zip 83854

3. LOCATION OF WELL by legal description:

N		Twp	50N	North	☒ or	South	☐
W		Rge	05W	East	☐ or	West	☒
E		Sec	23	1/4	NE	1/4	NE 1/4
S				10 Ac	40 Ac	160 Ac	
		Gov't Lot	County		Kootenai		
		Lat	Long				

Address of Well Site: (see next line)

Greens ferry rd S to bottom of hill on left do not g City _____

Lot _____ Blk _____ Sub. Name (see next line) _____

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	39	8 sacks	dry - pour in

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) _____

Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6"	1	39	0.25	Steel	☒	☐	☒	☐
4"	20	260	0.16	PVC	☐	☒	☐	☐
					☐	☐	☐	☐

Length Headpipe _____ Length Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations? Method Drill

☐ Screens? Screen Type _____

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
200	250	1/8"	500	1/8"	PVC	☐	☒
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

15 ft. below ground. Artesian pressure _____ lb.

Depth flow encountered 235 ft. Describe access port or

control devices: Steel Cap welded

11. WELL TESTS:

- ☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
8-10 est.	100%	260	1 hrs.

Water Temp. _____ cold Bottom hole temp. _____ cold

Water Quality test or comments: (below) Depth first Water Encountered 80

clear

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water
8"	0	32	Fill dirt	☐ Y ☒ N
8"	32	39	Decomposed granite	☐ Y ☒ N
6"	39	87	Decomposed fractured granite	☒ Y ☐ N
			1.5 GPM - heavy iron	☐ Y ☐ N
			2 shale traps installed 80 & 100 feet	☐ Y ☐ N
6"	87	142	Soft Decomposed granite	☐ Y ☒ N
6"	142	260	Hard black 7 white granite	☒ Y ☐ N
			6-8 GPM @ 235'	☐ Y ☐ N

Completed Depth 260 (Measurable)

Date: Started 6/12/98 Completed 6/17/98

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm United Drilling Inc. Firm No 414

Name _____ Date 6/17/98

Firm Official Timothy R. Volking and _____

Supervisor or Operator Timothy R. Volking Date 6/17/98