

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only		
Inspected by		
Twp	Rge	Sec
Lat	1/4	1/4
Long		

1. WELL TAG NO. D0035382

Drilling Permit No: _____

Other IDWR No. _____

2. OWNER

Well Number: _____

Name Schaefer, Roger & Carol

821

Address 4450 E Sterling Drive


City Post Falls

State ID

Zip 83854

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 50



North or ☐ South

Rge. 05



East or ☒ West

Sec. 15



1/4 NE 1/4 NE 1/4

Gov't Lot _____

County KOOTENAI

Lat: _____

: _____

Long: _____

: _____

: _____

Address of Well Site 12076 W. Cayote Lan

City Post Falls

(Give at least name of road + Distance to Road or Landmark)

Lt. 5

Blk. 1

Sub. Name Raccoon Ridge

11. WELL TESTS:



Pump



Ballor



Air



Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
40-			1hr

Water Temp. Cold _____ Bottom Hole Temp Cold _____

Water Quality test or comments: Clear

Depth first Water encountered 73

12. LITHOLOGIC LOG:(Describe repairs or abandonment

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	
				Y	N
8	0	2	Top Soil	☐	☒
8	2	8	Sand & Gravels	☐	☒
8	8	26	Sand w/Decomp Granite	☐	☒
8	26	38	Decomp Granite Soft	☐	☒
6	38	72	Decomp Granite Med Soft	☐	☒
6	72	73	Decomp Granite Broken 1gpm	☒	☐
6	73	137	Granite Gray	☐	☒
6	137	169	Granite S&P w/Brown 2gpm	☒	☐
6	169	199	Granite S&P	☐	☒
6	199	210	Granite S&P w/gm 35+gpm	☒	☐
6	210	320	Granite S&P w/rose & green seams	☐	☒

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation

☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT Sacks or Pounds	METHOD
Material	From	To		
BENTONITE	0	38	300 lbs	Overbore

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 38

Was drive shoe seal tested? ☐ Y ☒ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	38	.250	Steel	☒	☐	☒	☐
4	-20	320	.200	PVC	☐	☒	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations Method Skill saw

☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
280	320	1/8x6	80	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

70 ft. below ground Artesian pressure _____ lb.

Depth flow encountered _____ ft. Describe access port or control devices: _____

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official Mark Penick Date 09/13/04

and _____

Supervisor or Operator Mark Penick Date 09/10/04

(Sign Once if Firm Official and Operator)

Mark Penick