

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

1. WELL OWNER

Name Art Lupper
Address E 14001 Rockwell Ave
Spokane, WASH.
Owner's Permit No. _____

7. WATER LEVEL

Static water level 90 feet below land surface
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Temperature cold ° F. Quality good
Artesian closed-in pressure _____ p.s.i.
Controlled by ☐ Valve ☐ Cap ☐ Plug2. NATURE OF WORK 95-76-N-16☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning)

8. WELL TEST DATA

☐ Pumo ☐ Bailer ☒ Other

Discharge G.P.M. Draw Down Hours Pumped

40 2 2

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type)
☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

4. METHOD DRILLED

☐ Cable ☒ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 145 feet
Casing schedule: ☒ Steel ☐ Concrete

Thickness	Diameter	From	To
<u>1.30</u> inches	<u>6</u> inches	<u>1</u> feet	<u>110</u> feet
<u>4.00</u> inches	<u>4</u> inches	<u>105</u> feet	<u>145</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was casing drive shoe used? ☒ Yes ☐ No
Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☐ Yes ☒ No
How perforated? ☐ Factory ☐ Knife ☐ Torch
Size of perforation _____ inches by _____ inchesNumber 100 From 105 feet To 145 feet
perforations _____ feet _____ feet
perforations _____ feet _____ feetWell screen installed? ☐ Yes ☒ NoManufacturer's name _____
Type _____ Model No. _____
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Diameter _____ Slot size _____ Set from _____ feet to _____ feetGravel packed? ☐ Yes ☐ No Size of gravel _____
Placed from _____ feet to _____ feetSurface seal depth 101 Material used in seal ☐ Cement grout
☒ Pudding clay ☐ Well cuttingsSealing procedure used ☐ Sherry pit ☐ Temporary surface casing
☒ Overbore to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location.

East 65th St
Tax # 6002
Subdivision Name _____
Lot No. _____ Block No. _____

County Kootenai
_____ 1/4 Sec. 17, T. 58 N. R. 4 W.

10.

Work started 6-16-76 finished 6-17-76

11. DRILLERS CERTIFICATION

Firm Name Don Drilling & Dev. Inc. Firm No. 100Address 1499 Cedar St. Date 6-19-76Signed by (Firm Official) Richard B. Brown, Presidentand
(Operator) E. M. Lewis