

48N 04W - 07 - 560

WATSON PIN 50N02W-32-7800



## WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well. JAN 16 1978

## 1. WELL OWNER

Name Rocky Watson  
or MARY  
Address 314 Bonita Dr. Post Falls, ID 83854  
Owner's Permit No. 95-77-N-127

## 7. WATER LEVEL

Department of Water Resources  
Static water level 40 feet below land surface  
Flowing? ☐ Yes ☒ No G.P.M. flow \_\_\_\_\_  
Temperature Cold ° F. Quality Good  
Artesian closed-in pressure \_\_\_\_\_ p.s.i.  
Controlled by ☐ Valve ☒ Cap ☐ Plug

## 2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement  
☐ Abandoned (describe method of abandoning)

## 8. WELL TEST DATA

☐ Pump ☐ Bailer ☒ Other

| Discharge G.P.M. | Draw Down | Hours Pumped |
|------------------|-----------|--------------|
| <u>40 GPM</u>    | <u>3</u>  | <u>1 hr</u>  |

## 3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type) \_\_\_\_\_  
☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

## 9. LITHOLOGIC LOG

| Hole<br>Diam. | Depth     |           | Material      | Water    |          |
|---------------|-----------|-----------|---------------|----------|----------|
|               | From      | To        |               | Yes      | No       |
| <u>8</u>      | <u>0</u>  | <u>32</u> | <u>Clay</u>   |          | <u>Y</u> |
|               | <u>32</u> | <u>40</u> | <u>Gravel</u> |          | <u>Y</u> |
|               | <u>40</u> | <u>98</u> | <u>"</u>      | <u>Y</u> |          |

## 4. METHOD DRILLED

☐ Cable ☒ Rotary ☐ Dug ☐ Other

## 5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 98 feetCasing schedule: ☒ Steel ☐ Concrete

| Thickness          | Diameter        | From          | To             |
|--------------------|-----------------|---------------|----------------|
| <u>.250</u> inches | <u>6</u> inches | <u>1</u> feet | <u>40</u> feet |
| _____ inches       | _____ inches    | _____ feet    | _____ feet     |
| _____ inches       | _____ inches    | _____ feet    | _____ feet     |
| _____ inches       | _____ inches    | _____ feet    | _____ feet     |
| _____ inches       | _____ inches    | _____ feet    | _____ feet     |

Was casing drive shoe used? ☒ Yes ☐ NoWas a packer or seal used? ☐ Yes ☒ NoPerforated? ☐ Yes ☒ NoHow perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation \_\_\_\_\_ inches by \_\_\_\_\_ inches

| Number             | From       | To         |
|--------------------|------------|------------|
| _____ perforations | _____ feet | _____ feet |
| _____ perforations | _____ feet | _____ feet |
| _____ perforations | _____ feet | _____ feet |

Well screen installed? ☐ Yes ☒ No

Manufacturer's name \_\_\_\_\_

Type \_\_\_\_\_ Model No. \_\_\_\_\_

Diameter \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Diameter \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Gravel packed? ☐ Yes ☒ No Size of gravel \_\_\_\_\_

Placed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface seal depth 23 Material used in seal ☐ Cement grout☒ Pudding clay ☒ Well cuttingsSealing procedure used ☐ Slurry pit ☒ Temporary surface casing☒ Overbore to seal depth

## 10.


Work started 7/7/77 finished 7/8/77

## 11. DRILLERS CERTIFICATION

Firm Name Associated Well Drillers Inc. No. 245Address Box 723, C.D.A. Idaho Date 7/8/77Signed by (Firm Official) Robert F. Dwyerand  
(Operator) Robert F. Dwyer

## 6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name \_\_\_\_\_

Lot No. \_\_\_\_\_ Block No. \_\_\_\_\_

County KootenaiSec. 36 T. 48 N. R. 4 W.

USE ADDITIONAL SHEETS IF NECESSARY

FORWARD THE WHITE COPY TO THE DEPARTMENT