

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

Office Use Only			
Inspected by _____			
Twp _____	Rge _____	Sec _____	
1/4 _____	1/4 _____	1/4 _____	
Lat: : : _____	Long: : : _____		

1. WELL TAG NO. D0010715

DRILLING PERMIT N _____

Other IDWR No _____

2. OWNER:

Name **Ken Gonser**

Address 4505 Dodd RD

City Hayden

State ID

Zip 83835

3. LOCATION OF WELL by legal description:

N				Twp	52N	North	☒ or	South	☐
W				Rge	03W	East	☐ or	West	☒
E				Sec	32	SW 1/4	SE 1/4	SE 1/4	
						10 Ac	40 Ac	160 Ac	
				Gov't Lot		County Kootenai			
				Lat		Long			
S				Address of Well Site: (see next line)					

4505 Dodd Road

City

Lot _____ Blk _____

Sub. Name (see next line)

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	18	6 sacks	pour in

Drive Shoe Used? ☐ Y ☒ N Shoe Depth(s) _____

Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	2	125	0.25	Steel	☒	☐	☒	☐
4	100	240	0.165	PVC	☐	☒	☐	☐
					☐	☐	☐	☐

Length Headpipe _____ Length Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations? Method Drill

☐ Screens? Screen Type _____

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
180	240		600	3/8	PVC	☐	☒
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

125 ft. below ground. Artesian pressure _____ lb.

Depth flow encountered 125 ft. Describe access port or

control devices: Steel cap welded

11. WELL TESTS:

- ☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
25	100%	235	1 hr.

Water Temp. _____ cold Bottom hole temp. _____ cold

Water Quality test or comments: (below) Depth first Water Encountered 125

clear, cold, no smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
				Y	N
8	0	4	Topsoil & cobbles	☐	☐
8	4	35	Clay - brown/orange	☐	☐
8	35	40	Clay - orange with sand	☐	☐
8	40	60	Clay - brown/tan	☐	☐
6	60	70	Clay - brown	☐	☐
6	70	75	Clay - brown/black	☐	☐
6	75	113	Clay - brown/black	☐	☐
6	113	125	Hard pan - black & gray - broken	☐	☐
			water - 8 gpm	☐	☐
6	125	230	Basalt - hard - black	☐	☐
6	230	240	Basalt - hard - black	☐	☐
			17 gpm @ 230	☐	☐

Completed Depth 240 (Measurable)

Date: Started 10/20/99 Completed 10/21/99

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm United Drilling Inc.

Firm No 414

Name

Firm Official

and

Supervisor or Operator Jason C. Beckham

Date 10/22/99

Date 10/22/99

95-14458 SCANNED
OCT 20 2009