

USE TYPEWRITER OR
BALL POINT PEN

State of Idaho
Department of Water Resources

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

ENT'D

RECEIVED

NOV 17 1975

1. WELL OWNER

Name Edward Boyer
Address 1221 PENN, COEUR D'ALENE, IDA.
Owner's Permit No. 96-75-N-2

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning)

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type)
☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

4. METHOD DRILLED

☐ Cable ☒ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION


Diameter of hole 6 inches Total depth 300 feet
Casing schedule: ☒ Steel ☐ Concrete
Thickness Diameter From To
1.250 inches 6 inches + 1 feet 165 feet
_____ inches _____ inches _____ feet _____ feet
_____ inches _____ inches _____ feet _____ feet
_____ inches _____ inches _____ feet _____ feet
_____ inches _____ inches _____ feet _____ feet
Was casing drive shoe used? ☒ Yes ☐ No
Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☐ Yes ☒ No
How perforated? ☐ Factory ☐ Knife ☐ Torch
Size of perforation _____ inches by _____ inches
Number From To
_____ perforations _____ feet _____ feet
_____ perforations _____ feet _____ feet
_____ perforations _____ feet _____ feet

Well screen installed? ☐ Yes ☒ No
Manufacturer's name _____
Type _____ Model No. _____
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Gravel packed? ☐ Yes ☒ No Size of gravel _____
Placed from _____ feet to _____ feet

Surface seal depth 21 Material used in seal ☐ Cement grout
☒ Pudding clay ☐ Well cuttings
Sealing procedure used ☐ Slurry pit ☐ Temporary surface casing
☒ Overbore to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name _____
Lot No. _____ Block No. _____

County Kootenai

NW 1/4 NW 1/4 Sec. 3, T. 52 N., R. 3 E.

7. WATER LEVEL

Static water level 160 feet below land surface
Flowing? ☐ Yes ☐ No G.P.M. flow _____
Temperature _____ ° F. Quality _____
Artesian closed-in pressure _____ p.s.i.
Controlled by ☐ Valve ☐ Cap ☐ Plug

8. WELL TEST DATA

☐ Pump ☐ Bailer ☒ Other AIR
Discharge G.P.M. 80 Draw Down _____ Hours Pumped _____

9. LITHOLOGIC LOG

Hole Diam.	Depth		Material	Water	
	From	To		Yes	No
6	0	50	Red Hard Pan Clay		X
	50	120	SOFT Reddish-Brown light clay		X
	120	160	Brown Clay		X
	160	170	BROKEN BASALT + Brown clay		X
	170	180	Hard Gray Basalt		X
	180	181	BROKEN Gray Basalt - 15cm		X
	181	285	Hard Gray Basalt		X
	285	290	BROKEN Gray Basalt 6.5' x 6.5m		X
	290	300	Hard Gray Basalt		X

10.

Work started 8-13-75 finished 8-15-75

11. DRILLERS CERTIFICATION

Firm Name Coeur d'Alene Drilling Firm No. 214
Address P.O. Box 386 Hayden Lake, Ida. Date 8-18-75
Signed by (Firm Official) Edward Boyer
and Edward Boyer
(Operator)

95-14689

SCANNED

NOV 17 2009