POSTED

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter or Ball Point Pen

1. DRILLING PERMIT NO. 95 - 94 - N - 266 - 000
Other IDWR No.

2. OWNER:
Name MIKE KLIKA
Address P.O.BOX 2546
City HAYDEN State ID Zip 83835

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S — X

Twp. 52N North ☒ or South ☐
Rge. 3W East ☐ or West ☒
Sec. 32, 1/4 SW 1/4 SW 1/4 (10 acres / 40 acres / 160 acres)
Gov't Lot ____ County KOOTENAI

Address of Well Site END OF BOOT HILL RD. City
(Give at least name of road + Distance to Road or Landmark)

Lt. ____ Blk. ____ Sub. Name ____

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
BENTONITE	0	110	12	OVERBORE

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 220'
Was drive shoe seal tested? Y ☐ N ☒ How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2	220	.250	STEEL	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe ____ Length of Tailpipe ____

9. PERFORATIONS/SCREENS
☒ Perforations Method DOWN HOLE PERFORATOR
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
180	210		400	¼X1"	STEEL	☒	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
80' EST below ground Artesian pressure ____ lb.
Depth flow encountered ____ ft. Describe access port or control devices: CAP

SWSW 32 52N 3W

11. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
20 EST.	N/A	180	2 HRS.

Water Temp. COLD Bottom hole temp. COLD
Water Quality test or comments: CLEAR NO ODOR

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
8"	0	1	SOIL		X
	1	19	CLAY RED BROWN		X
	19	68	CLAY BROWN TAN		X
	68	106	CLAY DARK BROWN		X
6"	106	180	BASALT BLACK HARD		X
	180	200	BASALT BROKEN MED	X	
	200	210	SAND COARSE	X	
	210	230	CLAY DARK BROWN		X

RECEIVED JAN 5 1995 IDWR

MICROFILMED JAN 0 9 1998

Completed Depth 220' (Measurable)
Date: Started 11/9/94 Completed 11/11/94

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name UNITED DRILLING INC. Firm No. 414
Firm Official [signature] Date 11-14-94
and
Supervisor or Operator Lacey Vandulwelmte Date 11/14/94
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES 95-14690

SCANNED NOV 17 2009