

Form 2397
3/95

Starships Consulting and
Management Services

1235

1. DRILLING PERMIT NO. 95-95-N-0204-000
Other IDWELL R

2. OWNER


Name GIULIANI, OLIVER

Address 2005 CASCADE CT.

City POST FALLS State ID Zip 83854

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 52 ☒ North or ☐ South

Rge. 03 ☐ East or ☒ West

Sec. 32 1/4 SW 1/4 NE 1/4

Gov't Lot County KOOTENAI

Lat. : : Long. : :

Address of Well Site BOOTHILL RD

City

(Give at least name of road + Distance to Road or Landmark)

Lt. Blk. Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Secks or Pounds	
BENTONITE	0	30+	GALS/2B	SLURRY/ DRY

Was drive shoe used? ☐ Y ☐ N Shoe Depth(s) 0

Was drive shoe seal tested? ☐ Y ☐ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner Welded	Threaded
6	+2.5	71	.250	STEEL	☒	☐	☐
4	-40	140	.160	PSI PVC	☐	☒	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations Method SKILLSAW

☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
100	140	1/8X4	140	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

46 ft. below ground Artesian pressure lb.

Depth flow encountered ft. Describe access port or control devices:

32 52N 3W
SE NE

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

Office Use Only	
Inspected by TDK	
Twp. 52N Rge. 03 Sec. 32	
1/4 SE 1/4 NE 1/4	
Lat. : : Long. : :	

11. WELL TESTS:

☒ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
10+ GPM			
12 GPM	PUMP TEST		4 Hours

Water Temp. Bottom Hole Temp

Water Quality test or comments:

Depth first Water encountered

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	
				Y	N
10	0	12	Clay W/Gravel 3" minus yellow tan	☐	☒
10	12	18	Clay, Tan, Medium	☐	☒
8	18	24	Clay Tan Medium	☐	☒
8	24	28	Clay Redish Brown Medium	☐	☒
8	28	40	Clay Tan Med 1 gpm	☒	☐
8	40	67	Clay Brown Medium	☐	☒
8	67	71	Clay Black Med Soft	☐	☒
6	71	113	Basalt Dark Gray	☐	☒
6	113	117	Basalt Fractured Gray Soft 10 gpm	☒	☐
6	117	140	Basalt Dark Gray	☐	☒
	0	0	Note: Set 100' of 160 psi liner/1 weld o	☐	☐

MICROFILMED

JAN 09 1998

Completed Depth 140' (Measurable)
Date: Started 01/02/96 Completed 01/02/96

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official John Whelan Date 1-23-96

and Supervisor or Operator J.E.H. Date 1-15-96

(Sign Once if Firm Official and Operator)

95-14417

SCANNED

OCT 13 2009