

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0056456

Drilling Permit No. _____
Water right or injection well # _____

2. OWNER

Name Mike Curry
Address 1400 Northwood Center Court, Suite A
City Coeur d'Alene State ID Zip 83814

3. WELL LOCATION:

Twp. 51 North ☒ or South ☐ Rge. 5 East ☐ or West ☐
Sec. 18 1/4 SE 1/4 NE 1/4
10 acres 40 acres 160 acres

Gov't Lot _____ County Kootenai
Lat. _____ (Deg. and Decimal minutes)
Long. _____ (Deg. and Decimal minutes)
Address of Well Site 17489 W. Julia Drive

City Hauser
(Give at least name of road + Distance to Road or Landmark)
Lot. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection
☐ Other _____

5. TYPE OF WORK check all that apply

(Replacement etc.)

☒ New Well ☐ Replacement well ☐ Modify existing well
☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES

Seal material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method/procedure
Bentonite	0	31	450 lbs	Dry Pour
Granular				

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
6"	+2	31	.250	Steel	☒	☐	☐	☒
4"	-20	400	.200	PVC	☐	☒	☐	☐

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 31 FT

9. PERFORATIONS/SCREENS:

Perforations ☒ Y ☐ N Method Drilled 3/8" Round Holes

Manufactured screen ☐ Y ☒ N Type _____

Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
360	400	3/8"	120	4"	PVC	.200

Length of Headpipe _____ Length of Tailpipe _____
Packer ☐ Y ☒ N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft³)	Placement method
-----------------	-----------	---------	-----------------------	------------------

11. FLOWING ARTESIAN:

Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG) _____
Describe control device Steel Cap Welded

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 90 Static water level (ft) 50
Water temp. (°F) _____ Bottom hole temp. (°F) _____

Describe access port _____

Well test:

Test method:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
100%	10	1 Hour	☐	☐	☒	☐

Water Quality test or comments: Clear, Cold, No Smell

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water Y	Water N
8	0	2	Top soil		X
8	2	8	Sand & gravel fine with decomposed granite		X
8	8	28	Granite decomposed brown/white soft		X
8	28	31	Granite brown/white soft		X
6	31	70	Granite brown/white soft		X
6	70	90	Granite black/white/brown soft	X	
6	90	400	Granite purple/black/white soft	X	
			1 GPM @ 90 ft		
			5 GPM @ 140 ft		
			2 GPM @ 310 ft		
			2 GPM @ 380 ft		

UNITED CROWN
PUMP & DRILLING
3125 W Hayden Ave. Hayden ID 83835
Office (208) 682-0651 (208) 772-7867

Completed Depth (Measurable) 400
Date: Started 5-18-09 Completed 5-19-09

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name United Crown Pump & Drilling Co. No. 636

*Principal Driller Jason Beckham Date 5-21-09

*Driller [Signature] Date 5-21-09

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.



October 8, 2009

To Whom It May Concern:

United Crown Pump & Drilling completed the drilling of a well on May 21, 2009, for Mike Curry at the location of 17489 W. Julia Drive, Hauser, ID 83854. At this time, Mr. Curry requested that United Crown Pump & Drilling install temporary electrical and a temporary domestic pump system to be used to supply domestic water to the onsite construction trailer. This system has been in use since May 28, 2009. Please feel free to contact me at our Hayden office if you have additional questions or need farther information.

Sincerely,

United Crown Pump & Drilling

A handwritten signature in black ink, appearing to read "Richard A. Agueros".

Richard A. Agueros, President

Sales • Service • Installation • Well Drilling • Pump Systems
Residential • Commercial • Municipal

3125 W. Hayden Ave. • Hayden, ID 83835 • (208) 772-7867 • (800) 682-9641 • Fax (208) 772-7229

95-14407

SCANNED

OCT 14 2009