Form 238-7
6/93

ENT'D

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

RECEIVED APR 14 1994
Department of Water Resources
092274

Use Typewriter or Ball Point Pen

1. DRILLING PERMIT NO. 94-C-0079-000
Other IDWR No.

2. OWNER:
Name Janene Licha & Jenette Villa Gomez
Address 5335 Lubad
City Woodland Hills State CA Zip 91364

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S

T. 52 North ☒ or South ☐
R. 3 East ☐ or West ☒
Sec. 31, SW 1/4 (10 acres) SW 1/4 (40 acres) SW 1/4 (160 acres)
Gov't Lot 4 County Kootenai

Address of Well Site 1675 Dodd RD.
(Give at least Direction + Distance to Road or Landmark)
Lot No. Block No. Subd. Name

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
Bentonite	0	20	6	over bored

Was drive shoe seal tested? YES NO How?

8. CASING/LINER:

Diameter	From	To	Guage	Casting	Liner	Steel	Plastic	Welded	Threaded
6	1½	20	.250	X		☐	☐	☐	☐
4	-4	260	Class 160		X	☐	☒	glued	☐
						☐	☐	☐	☐
						☐	☐	☐	☐

Final location of shoes 20
Top Packer or Headpipe Bottom Tailpipe

9. PERFORATIONS/SCREENS
☒ Perforations Method Saw Cut
☐ Screens Type Material

From	To	Slot Size	Number	Diameter	Tele/Pipe Size	Casting	Liner
225	125	1/8	50	4		☐	☒
						☐	☐
						☐	☐
						☐	☐

SWSWSW 31 52N 3W
Govt Lot 4

10. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Depth	Time
12.5			6 hours

Temperature of water Was a water analysis done? Yes ☐ No ☐
By whom?
Water Quality (odor, etc.) water Clear and Cold
Bottom Hole Temperature

11. STATIC WATER LEVEL:
32 ft. below surface Depth artesian flow found
Artesian pressure lb. Describe access port
Describe Controlling Devices:

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	GPM	SWL
8	0	2	Top Soil		
8	2	20	Basalt		
6	20	30	Basalt		
6	30	32	Basalt, Fractured	1.5	X
6	32	210	Basalt		
6	210	213	Fractured Basalt	4	
6	213	250	Fractured Basalt		
6	250	252	Fine Sand,	4	
6	252	355	Blue Clay		
6	355	357	Gravely Shale	3	
6	357	375	Blue Clay		

RECEIVED
MAR 14 1994
NORTHERN REGION
DWR

FEB 09 1995

Date: Started 2-14-94 Completed 2-16-94

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name HESTER DRILLING INC Firm No. 528
Firm Official Date 2-21-94
and
Supervisor or Operator C. Mark Horsley Date 2-16-94
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES

95-9389

SCANNED
OCT - 5 2009