

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

Name Frank Kelly
Address Medmont Id
Owner's Permit No. 94-79-N-3

Static water level 40 feet below land surface.
Flowing? ☐ Yes ☐ No G.P.M. flow _____
Artesian closed-in pressure _____ p.s.i.
Controlled by: ☐ Valve ☐ Cap ☐ Plug
Temperature _____ °F. Quality _____

☐ Pump ☐ Bailer ☒ Air ☐ Other

Discharge G.P.M.	Pumping Level	Hours Pumped
20		2

9. LITHOLOGIC LOG

Casing schedule: ☒ Steel ☐ Concrete ☐ Other _____

Thickness	Diameter	From	To
<u>250</u> inches	<u>6</u> inches	<u>1</u> feet	<u>50</u> feet
_____ inches	<u>PVC</u> inches	<u>10</u> feet	<u>120</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was casing drive shoe used? ☒ Yes ☐ No
Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☐ Yes ☒ No

How perforated? ☐ Factory ☒ Knife ☐ Torch
Size of perforation _____ inches by _____ inches

Number	From	To
perforations	feet	feet
perforations	feet	feet
perforations	feet	feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name

Type _____ Model No. _____

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Diameter	Slot size	Set from	feet to	feet
----------	-----------	----------	---------	------

Gravel packed? ☐ Yes ☒ No ☐ Size of gravel

Placed from _____ feet to _____ feet

Surface seal depth 20 Material used in seal: ☐ Cement grout

☐ Puddling clay ☒ Well cuttings

Sealing procedure used: ☐ Slurry pit ☒ Temp. surface casing

☒ Overbore to seal depth

Method of joining casing: ☐ Threaded ☒ Welded ☐ Solvent

Weld

☐ Cemented between strata



Subdivision Name

Lot No. Block No.

11. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Hendrick's Mill Firm No. 322

Address Hudson Lake Date 5 Sept 79

Signed by (Eirm Official) *[Signature]*