

Nov. 20. 2009. 4:29PM

H2O WELL SERVICE INC

No. 2102 P. 2

Form 238-7
4/92STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORTState law requires that this report be filed with the Director, Department of Water Resources
within 30 days after the completion or abandonment of the well.USE TYPEWRITER OR
BALLPOINT PEN**RECEIVED**

JUL 16 1993

NORTHERN REGION
SAND SPRING W R**1. WELL OWNER**Name KARLEEN GIBSONAddress 319 Courtdale Lake Dr. CDA ID 83814

Drilling Permit No. _____

Water Right Permit No. 95-93-N-110-000**7. WATER LEVEL**Static water level 100 feet below land surface W RFlowing? ☐ Yes ☒ No

G.P.M. flow _____

Artesian closed-in pressure _____ p.s.i.

Controlled by: ☐ Valve ☐ Cap ☐ PlugTemperature _____ °F. Quality Brownish

Describe artesian or temperature zones below.

2. NATURE OF WORK

- ☒ New well ☐ Deepened ☐ Replacement
☐ Well diameter increase ☐ Modification
☐ Abandoned (describe abandonment or modification procedures
 such as liners, screens, materials, plug depths, etc. in lithologic
 log, section 9.)

8. WELL TEST DATA☐ Pump ☐ Baller ☒ Air ☐ Other

Discharge G.P.M.

Pumping Level

1 to 2 GPM**RECEIVED**

JUL 30 1993

NORTHERN REGION
IDWR**3. PROPOSED USE**

- ☒ Domestic ☐ Irrigation ☐ Monitor
☐ Industrial ☐ Stock ☐ Waste Disposal or Injection
☐ Other _____ (specify type)

9. LITHOLOGIC LOG

Bore Oam.	Depth		Material	Water	
	From	To		Yes	No
10	0	18	CEMENTED BASALT W/CLAY		X
5	18	23	CEMENTED BASALT W/CLAY		X
5	23	90	CLAY W/QUARTZ COURSE SAND LIGHT BROWN		X
8	80	170	CLAY W/QUARTZ COURSE SAND ORANGISH BROWN		X
8	170	170	GRANITE DECOMPOSED BROWN		X
6	178	190	GRANITE WHITE W/GREEN & ROSE W/SOME BROWN SOFT		X
6	190	196	GRANITE WHITE GREEN SOFT W/WATER APPROXIMATE 1 to 2 gpm		X
6	198	231	GRANITE WHITE & BLACK MED		X
6	231	250	GRANITE WHITE/BLACK W/BROWN SOFT		X
6	250	271	GRANITE WHITE W/GREEN MED		X
6	271	296	GRANITE BLACK & WHITE W/SOME ROSE		X
6	296	320	GRANITE WHITE W/GREEN W/ROSE MED SOFT		X
6	328	345	GRANITE WHITE & BLACK MED		X
6	345	350	GRANITE BLACK & WHITE SOME GREEN MED		X
6	350	360	GRANITE WHITE W/GREEN W/ROSE MED SOFT		X

4. METHOD DRILLED

- ☒ Rotary ☒ Air ☐ Auger ☐ Reverse rotary
☐ Cable ☐ Mud ☐ Other _____
 (backhoe, hydraulic, etc.)

5. WELL CONSTRUCTIONCasing schedule: ☒ Steel ☐ Concrete ☐ Other

Thickness 2.50 inches Diameter 6 inches + 2.5 feet 17.5 feet
160psi inches 8 inches 5 feet 320 feet
 inches inches feet feet

Was casing drive shoe used? ☒ Yes ☐ NoWas a packer or seal used? ☐ Yes ☒ NoPerforated? ☒ Skill Saw ☐ Yes ☐ NoHow perforated? ☐ Factory ☐ Knife ☐ Torch ☐ GunSize of perforation? 1/8 inches by 4 inches

Number From To

30 perforations 300 feet 320 feet30 perforations 240 feet 260 feet30 perforations 100 feet 190 feetWell screen installed? ☐ Yes ☒ No

Manufacturer _____ Type _____

Top Packer or Headpipe _____

Bottom of Telltale _____

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes ☒ No ☐ Size of gravel _____


Placed from _____ feet to _____ feet

Surface seal depth 60 Material used in seal: ☐ Cement grout☒ Bentonite ☐ Puddling clay ☐ _____Sealing procedure used: ☒ Slurry pit☐ Temp. surface casing ☒ Overbore to seal depthMethod of joining casing: ☐ Threaded ☒ Welded☐ Solvent Weld

Describe access port _____

6. LOCATION OF WELL

Sketch map location must agree with well location on map



Subdivision Name _____

Lot No. _____ Block No. _____

County KootenaiAddress of Well Site Taylor's Terrace Area

(give at least name of road)

SW 3W 34 2 202 N ☐ or S ☐W W 34 2 202 E ☐ or W ☒**10.**Work started 06/21/93 finished 06/23/93**11. DRILLER'S CERTIFICATION**We certify that all minimum well construction standards were
complied with at the time the rig was removed.Firm Name H2O WELL SVC INC Firm No. 8440Address 582 W PAYDEN AVE Date 06/23/93Signed by Drilling Supervisor [Signature]

and

(Operator) [Signature]

(If different than the Drilling Supervisor)

USE ADDITIONAL SHEETS IF NECESSARY - FORWARD THE WHITE COPY TO THE DEPARTMENT

95-14761

SCANNED

NOV 30 2009