Form 238-7
1/78

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

USE TYPEWRITER OR BALLPOINT PEN

N R

1. WELL OWNER

Name Henry & Nichols

Address 5320 Mesa Rd. Post Falls, Idaho

Owner's Permit No. 95-80-N-39

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning) _____

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal
☐ Industrial ☐ Stock ☐ Waste Disposal or Injection
☐ Other _____ (specify type)

4. METHOD DRILLED

☒ Rotary ☐ Air ☐ Hydraulic ☐ Reverse rotary
☐ Cable ☐ Dug ☐ Other _____

5. WELL CONSTRUCTION

Casing schedule: ☒ Steel ☐ Concrete ☐ Other _____

Thickness	Diameter	From	To
.250 inches	6 inches	+ 1 feet	36 feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was casing drive shoe used? ☒ Yes ☐ No
Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☒ Yes ☐ No
How perforated? ☐ Factory ☐ Knife ☒ Torch
Size of perforation 1/4 inches by 8 inches

Number	From	To
8 perforations	30 feet	36 feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☒ No
Manufacturer's name _____
Type _____ Model No. _____
Diameter ___ Slot size ___ Set from _____ feet to _____ feet
Diameter ___ Slot size ___ Set from _____ feet to _____ feet
Gravel packed? ☒ Yes ☐ No ☐ Size of gravel 1/4" Minus
Placed from 30 feet to 36 feet
Surface seal depth 20 Material used in seal: ☐ Cement grout ☒ Well cuttings ☒ Puddling clay
Sealing procedure used: ☐ Slurry pit ☐ Temp. surface casing ☒ Overbore to seal depth
Method of joining casing: ☐ Threaded ☒ Welded ☐ Solvent Weld ☐ Cemented between strata
Describe access port _____

6. LOCATION OF WELL

Sketch map location must agree with written location.

N / W / E / S

Subdivision Name _____
Lot No. _____ Block No. _____
County Kootenai
SE ¼ SE ¼ Sec. 13, T. 50 N/S, R. 6 E/W.

7. WATER LEVEL

Static water level 20 feet below land surface.
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Artesian closed-in pressure _____ p.s.i.
Controlled by: ☐ Valve ☒ Cap ☐ Plug
Temperature cold °F. Quality Good

8. WELL TEST DATA

☐ Pump ☐ Bailer ☐ Air ☐ Other _____

Discharge G.P.M.	Pumping Level	Hours Pumped
50	—	1½

9. LITHOLOGIC LOG

Hole Diam.	Depth From	Depth To	Material	Water Yes	Water No
8	0	4	Topsoil		X
	4	30	Decomposed Granite		X
	30	36	Granite	X	
	36	75	Granite	X	
			5 GPM at 32'		
			45 GPM at 68'		

RECEIVED
MAR 30 1981
Department of Water Resources

10. Work started 11/7/80 finished 11/7/80

11. DRILLERS CERTIFICATION cb dL

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Associated Well Drillers Inc Firm No. 245
Address Box 723 CDA Date 11/7/80
Signed by (Firm Official) Bud Thornton
and
(Operator) Robert J Dight

USE ADDITIONAL SHEETS IF NECESSARY — FORWARD THE WHITE COPY TO THE DEPARTMENT