

IDWR/North

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat: : :	Long: : :		

1. WELL TAG NO. D0013414

DRILLING PERMIT NO

Other IDWR No. 765233

2. OWNER:

Name Peter Wallner

Address 10780 SW Cowan Road

City Vashon Island

State WA

Zip 98070

3. LOCATION OF WELL by legal description:

N		Twp 52N		North ☒ or South ☐	
W		Rge 03W		East ☐ or West ☒	
E		Sec 32		1/4 NE 1/4 SW 1/4	
S		10 Ac		40 Ac 160 Ac	
Gov't Lot		County Kootenai			
Lat		Long			

Address of Well Site: (see next line)

Dodd Rd to Boot Hill Rd, 2nd drive

City

Lot

Blk

Sub. Name (see next line)

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	55	10 sacks	dry pour

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) -55

Drive Shoe Seal Tested? ☐ Y ☒ N How?

8. CASING/LINER

Diam	From	To	Gauge	Material	Casing	Liner	Weld	Thrded
6	1	-55	0.250	Steel	☒	☐	☒	☐
4	-45	-165	0.165	PVC	☐	☒	☐	☐
					☐	☐	☐	☐

Length Headpipe

Length Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations? Method drill

☐ Screens? Screen Type

From	To	Slot	Nmbr	Diam	Material	Casing	Liner
-105	-165		600	3/8	PVC	☐	☒
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

80 ft. below ground. Artesian pressure lb.

Depth flow encountered 164 ft. Describe access port or

control devices: Steel cap welded

11. WELL TESTS

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
3	100%	160	1 hr.

Water Temp. cold

Bottom hole temp. cold

Water Quality test or comments: (below) Depth first Water Encountered 164

clean, cold, no smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
				Y	N
8	0	-54	Clay, brown	☐	☒
8	54	55	Basalt, black, hard	☐	☒
6	55	160	Basalt, black, hard	☐	☒
6	160	165	Basalt, broken	☒	☐
				☐	☐

Completed Depth 165 (Measurable)

Date: Started 6/26/00 Completed 6/28/00

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc.

Firm No 414

Firm Official

Tim Wallner

Date 6/29/00

Supervisor or Operator Curtis S. Hammond

Date 6/29/00

FORWARD WHITE COPY TO WATER RESOURCES

299

52N 3W 32

POU

52N03W32SESW

WELL

