

WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

Office Use Only			
Inspected by _____			
Twp _____	Rge _____	Sec _____	
1/4 _____		1/4 _____	
Lat : : _____	Long : : _____		

1. DRILLING PERMIT NO. TAG#D0003100

Other IDWR No. _____

2. OWNER

Name POLLARD, JOHN


Well Number: 581

Address PO BOX 577

City ST MARIES State ID Zip 83861

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 46 ☒ North or ☐ South

Rge. 01 ☐ East or ☒ West

Sec. 13 1/4 NE 1/4 NW 1/4

Gov't Lot _____ County BENEWAH

Lat. : : _____ Long. : : _____

Address of Well Site ALPINE CREEK 2 MI

BENEWAH RD.

City BENEWAH

(Give at least name of road + Distance to Road or Landmark)

Blk. _____

Sub. Name 13000 Hwy 5

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation

☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To		
BENTONITE	0	49	9 SACKS	GRANULAR POUL

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) _____

Was drive shoe seal tested? ☐ Y ☐ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	49	.250	STEEL	☒	☐	☒	☐
4	-8	305	.160	PVC	☐	☒	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations Method SKILLSAW

☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
265	305	1/8X6	150	4	VPC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

65 ft. below ground Artesian pressure _____ lb.

Depth flow encountered _____ ft. Describe access port or control devices: _____

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
50+			1.5HR

Water Temp. _____ Bottom Hole Temp _____

Water Quality test or comments: _____

Depth first Water encountered _____

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	
				Y	N
8	0	3	Topsoil	☐	☒
8	3	49	Clay Tan W/Shale Soft	☐	☒
6	49	80	Shale Gray Medium	☐	☒
6	80	85	Shale Gray W/Brown Soft	☒	☐
6	85	102	Shale Lt Gray Medium	☐	☒
6	102	138	Shale Dk Gray Medium	☐	☒
6	138	140	Shale Brown W/Green Soft	☒	☐
6	140	143	Shale Lt Gray W/ Brown	☐	☒
6	143	164	Shale Lt Gray Medium	☐	☒
6	164	165	Shale Brown W/Green Soft	☐	☒
6	165	194	Shale Lt. Gray Medium	☐	☒
6	194	199	Shale Brown W/Green Soft	☐	☐
6	199	222	Shale Lt. Gray Medium	☐	☒
6	222	230	Shale Brown W/Green Soft	☐	☒
6	230	275	Shale Lt. Gray Medium	☐	☒
6	275	286	Shale Gray Brown Green Soft	☐	☒
6	286	294	Shale Lt Gray Medium	☒	☐
6	294	297	Shale Gray W/Brown Medium	☐	☒
6	297	305	Shale Lt Gray Medium	☐	☒

Completed Depth 305' (Measurable)

Date: Started 7/28/97 Completed 7/29/97

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official _____ Date 7/29/97

and Supervisor or Operator _____ Date 7/29/97

(Sign Once if Firm Official and Operator)

(Todd Morgan)