

3/95 MAY 20 1998

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

NORTHERN REGION

IDWR

1. DRILLING PERMIT NO. 96-98-N-64 -
Other IDWR No. D0003419

2. OWNER:

Name Gloria Paquette
Address 2025 W. Hwy 53 #40
City Rathdrum State ID Zip 83858

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.



Twp. 54N North ☒ or South ☐
 Rge. 5W East ☐ or West ☒
 Sec. 22, SE 1/4 NE 1/4 SE 1/4
10 acres 40 acres 160 acres
 Gov't Lot _____ County Bonner
 Lat: _____ : _____ : _____ Long: _____ : _____ : _____
 Address of Well Site S. Santiago Rd.
 City Blanchard
 (Give at least name of road; Distances to Road or Landmark)

Lt. 1 Blk. Sub. Name Blanchard Valley
Farms

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
Bentonite	0	20	13 Sacks	Pour

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 138
Was drive shoe seal tested? ☐ Y ☒ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	138	.25	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe 2 Length of Tailpipe

9. PERFORATIONS/SCREENS

☐ Perforations Method _____

☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

80 ft. below ground Artesian pressure _____ lb.
Depth flow encountered _____ 87 ft. Describe access port or
control devices:

54N 5W 22 SE NE SE

11. WELL TESTS

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
20		130	1 Hr

Water Temp. _____ Bottom hole temp. _____

Water Quality test or comments: _____

Depth first Water Encountered _____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

[illegible]

Completed Depth 140 (Measurable)
Date: Started 13 May 98 Completed 13 May 98

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Fogle Pump & Supply, Inc. Firm No. 537

Firm Official James M. Doyle Date 15 May 98

and *Leptocarpus* *sp.*

Supervisor or Operator Martin Jensen/mo Date 15 May 98

(Sign once if Film Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES