

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat:	:	Long:	:

1. WELL TAG NO. 28062

Drilling Permit No: 789705
Other IDWR No.

2. OWNER

Name DANIEL, JEANETTE

Well Number:


539

Address P.O. BOX 203

City TENSED State ID Zip 83870

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 45 ☒ North or ☐ South
Rge. 4 ☐ East or ☒ West
Sec. 17 1/4 SE 1/4 SE 1/4

Gov't Lot County BENEWAH

Lat: : : Long: : :

Address of Well Site WINDFALL PASS RD.

City PLUMMER

(Give at least name of road + Distance to Road or Landmark)

Lt. Blk. Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK		AMOUNT		METHOD
Material	From	To	Sacks or Pounds	
DRY GRANULE				
BENTONITE	0	18	9 BAGS	OVERBORE

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 258

Was drive shoe seal tested? ☐ Y ☒ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	258	.250	STEEL	☒	☐	☒	☐
4	-243	363	.160	PVC	☐	☒	☒	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations Method SKILL SAW

☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
343	363	1/8 X 6	60	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

140 ft. below ground Artesian pressure lb.
Depth flow encountered 360 ft. Describe access port or control devices:

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
6			1 HR

Water Temp. COLD Bottom Hole Temp. COLD

Water Quality test or comments: CLEAR

Depth first Water encountered 168

12. LITHOLOGIC LOG:(Describe repairs or abandonmen

				Water	
Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Y	N
8	0	2	Top Soil	☐	☐
8	2	160	Brown Clay	☐	☐
8	160	170	Brown Clay	☐	☐
8	170	210	Brown Clay	☐	☐
8	210	241	Clay w/Gravel	☐	☐
8	241	258	Soft Brown Shale	☐	☐
6	258	311	Brown Shale	☐	☐
6	311	326	Gray Shale	☐	☐
6	326	363	Brown Shale w/ some Gray	☐	☐

Completed Depth 363 (Measurable)
Date: Started 2/10/03 Completed 2/12/03

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O Well Service, Inc. Firm No. 448

Firm Official Date

and Supervisor or Operator Date 2-13-03

(Sign Once if Firm Official and Operator)

45 ~ 4w 17