Form 238-7
7/98
Starships Consulting and Management Services

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only
Inspected by
Twp Rge Sec
1/4 1/4 1/4
Lat: : : Long: : :

1. WELL TAG NO. D0055357
Drilling Permit No: 85362e
Other IDWR No.

2. OWNER **Well Number:** 1445
Name KULIN, IRA & EMILY
Address P.O. BOX 186
City KINGSTON State ID Zip 83839

3. LOCATION OF WELL by legal description
sketch map location must agree with written location



Twp. 48N ☑ North or ☐ South
Rge. 01E ☑ East or ☐ West
Sec. 12 1/4 NE 1/4 SE 1/4
Gov't Lot County SHOSHONE
Lattitude: N47.35.225 Longitude: W117.31.796
Address of Well Site 238 FRENCH GULCH City KINGSTON
(Give at least name of road + Distance to Road or Landmark)
Lt. Blk. Sub. Name SCUDDERS ACRE

4. USE:
☑ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)
☑ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD
☑ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
GRANULE	0	18	500 LBS	POURED

Was drive shoe used? ☑ Y ☐ N Shoe Depth(s) 190
Was drive shoe seal tested? ☐ Y ☑ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Materia	Casing	Liner	Welded	Threaded
6	+3	190	.250	STEEL	☑	☐	☑	☐
4	-6	394	.200	PVC	☐	☑	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS
☑ Perforations Method SKILLSAW
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
364	394	1/4	120	4	PVC	☐	☑

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
107 ft. below ground Artesian pressure lb.
Depth flow encountere 365 ft. Describe access port or control devices:

48 N 01E 12

11. WELL TESTS:
☐ Pump ☐ Bailer ☑ Air Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
40+			1 HR

Water Temp. COLD Bottom Hole Temp COLD
Water Quality test or comments: CLEAR
Depth first Water encountered 365

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Diam			Remarks: Lithology, Water Quality, Temperature	Water Y	Water N
10	0	8	Brown Clay w/ Gravel	☐	☑
10	8	18	Tan & White Clay	☐	☑
8	18	190	Tan Clay w/ Soft Shale	☐	☑
6	190	195	Hard Quartz	☐	☑
6	195	230	Brown Shale	☐	☑
6	230	394	Gray Shale w/Tan & Green	☑	☐

RECEIVED
OCT 30 2008
IDWR/North

Completed Depth 394 (Measurable)
Date: Started 9/29/2008 Completed 10/2/2008

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H20 WellService, Inc. Firm No. 448
Firm Official Date 10/30/08
and
Supervisor or Operator Date 10/6/2008
JR CANTRALL (Sign Once if Firm Offical and Operator)