



IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Use Typewriter
or
Ball Point Pen

1. DRILLING PERMIT NO. 95 - 94 - N - 183 - 00
Other IDWR No. _____

2. OWNER:

Name MICHAEL SHAW
Address MARINE RT. EVERWELL BAY
City COEUR D'ALENE State ID Zip 83814

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

Twp. 49N North ☒ or South ☐
 Rge. 4W East ☐ or West ☒
 Sec. 11 $\frac{1}{4}$ NW $\frac{1}{4}$ SE $\frac{1}{4}$
 Gov't Lot _____ County KOOTENAI $\frac{10}{160}$ acres

Address of Well Site 1/2 ML PAST
LUTHERHAVEN City _____
 (Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. PROPOSED USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK

☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD

☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	40	5	OVERBORE

Was drive shoe used? Y ☒ N ☐

Was drive shoe seal tested? Y ☐ N ☒ How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	±1	43	.250	STEEL	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations Method _____

☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Lines
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

20' ft. below ground Artesian pressure lb.

Depth flow encountered _____ ft. Describe access port or _____

control devices:

ADJ 4 11 29N 41

11. WELL TESTS:

☐ Pump ☐ Bailer ☐ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
60+		40'	1 HR.

Water Temp. COLD Bottom hole temp. COLD
Water Quality test or comments: CLEAR

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
8"	0	2	TOP SOIL		X
	2	12	BROWN CLAY		X
	12	16	BASALT BLACK		X
	16	45	SAND & GRAVEL	X	

RECEIVED
SEP 23 1994
NORTHERN REGION
IDWR

OFFICE USE ONLY	
Inspected by <u>TPK</u>	
Twp <u>49N</u> Rge <u>04W</u> Sec <u>11</u>	
<u>1/4 SE</u>	<u>1/4 NW</u>

Completed Depth 45' (Measurable)
Date: Started 8/23/94 Completed 8/23/94

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name UNITED DRILLING INC. Firm No. 414

Firm Official Tim R. Volkje Date 8-24-94
and
Supervisor or Operator Clint Tenney Date 8/24/94

(Sign area if Elm Official or Operator)