

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only
Inspected by RFD
Twp 47N Rge 2W Sec
1/4 NE 1/4 NE 1
Lat: : : Long:

1. WELL TAG NO. D D 0022556
 DRILLING PERMIT NO. 781-930
 Other IDWR No. _____

POSTED

2. OWNER: Leroy Gentry
Name
Address 38029 South Highway 3
City St. Maries State ID Zip 83861

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N
 W E S
 Twp. 47 North ☒ or South ☐
 Rge. 2 East ☐ or West ☒
 Sec. 7 1/4 NE 1/4 NE 1/4
 Gov't Lot _____ County Kootenai
 Lat. : : Long. : :
 Address of Well Site Black Lake
 City St. Maries
 H:11
 (Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
Bentonite	0	3.0	105x	Pour around Pipe

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 15.2

Was drive shoe seal tested? ☐ Y ☐ N How? At

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2	-152	250	Steel	☒	☐	☐	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

Perforations Method Torch
Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
115	140	1/8"	16	6"	Steel	☒	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

118 ft. below ground Artesian pressure lb.
Depth flow encountered 115 ft. Describe access port or
control devices: 4" x 11" CPB

1. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Arte

Yield gal./min.	Drawdown	Pumping Level
5 gpm	Air-lift from	

Water Temp. 52° Bottom hole 1

Water Quality test or comments: Clear no odor

Depth first Water Env

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature
8"	0	2	Clay - tan sandy
	2	10	Clay - gray
	10	116	Basalt - Gray
	116	140	Basalt - Broken w/ua
	140	145	Clay - Brown
	145	152	Clay - Tan

RECEIVED

SEP 10 2022

IDWENorth

Completed Depth 152
Date: Started 7-30-02 Completed 8-

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name All-Ways Drilling, Inc Firm No. _____

Firm Official Shale & Wall Date 8-30

and

Driller or Operator Alvin Carris Date 8-30

(Sign once if Firm Official & Operator)