

REPORT OF WELL DRILLER
State of Idaho

RECEIVED
JUN 30 1966

Department of Reclamation

State law requires that this report shall be filed with the State Reclamation Engineer within 30 days after completion or abandonment of the well.

WELL OWNER:

Name Mrs. Barbara Hult

Address Box 473

St. Marie Idaho

Owner's Permit No. none 94-65-N-4

NATURE OF WORK (check): Replacement well ☐

New well ☒ Deepened ☐ Abandoned ☐

Water is to be used for: Domestic

METHOD OF CONSTRUCTION: Rotary ☐ Cable ☒

Dug ☐ Other ☐

(explain)

CASING SCHEDULE: Threaded ☐ Welded ☒

6 "Diam. from 0 ft. to 100 ft.

"Diam. from ft. to ft.

"Diam. from ft. to ft.

"Diam. from ft. to ft.

Thickness of casing: .250 Material:

Steel ☒ concrete ☐ wood ☐ other ☐

(explain)

PERFORATED? Yes ☒ No ☐ Type of

perforator used: cutting torch

Size of perforations: 1/16 " by 2 "

perforations from 0 ft. to 15 ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

WAS SCREEN INSTALLED? Yes ☐ No ☒

Manufacturer's name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

CONSTRUCTION: Well gravel packed? Yes ☐

No. ☒ size of gravel Gravel

placed from ft. to ft. Surface seal

provided? Yes ☐ No ☒ To what depth?

 ft. Material used in seal:

Did any strata contain unusable water? Yes ☒

No. ☒ Type of water:

Depth of strata ft. Method of sealing

strata off:

Surface casing used? Yes ☐ No. ☒

Cemented in place? Yes ☐ No ☐

Locate well in section

			X

Sec.

LOCATION OF WELL: County Kootenai

NE 1/4 Sec. 19 T. 47 N. 2 W

Use other side for additional remarks

Size of drilled hole: 6 " Total

depth of well: 100 ft Standing water

level below ground: 35 ft Temp.

Fahr. ° Test delivery: 5 gpm

or cfs Pump? ☐ Bail ☒

Size of pump and motor used to make test:

Length of time of test: 2 Hrs. Min.

Drawdown: 50 ft. Artesian pressure: ft.

above land surface Give flow cfs

or gpm. Shutoff pressure:

Controlled by: Valve ☐ Cap ☐ Plug ☐

No control ☐ Does well leak around casing?

Yes ☐ No ☐

DEPTH		MATERIAL	WATER YES OR NO
FROM	TO		

0	10	Brown Clay	no
10	20	Brown Clay	no
20	30	yellow Clay	no
30	35	yellow Clay	no
35	40	Brown Clay	no
40	45	yellow Clay	no
45	46	1/2 minus Gravel	yes
46	58	Brown Clay	no
58	60	Brown Clay	no
60	75	yellow Clay	no
75	85	yellow Clay	no
85	100	yellow Clay to gravel	yes

Work started: June 15 1965

Work finished: June 30 1965

Well Driller's Statement: This well was drilled under my supervision and this report is true to the best of my knowledge.

Name: James D. Sager

Address: 1109 Birch Rd

Signed by:

License No. 5237 Date: June 17 66

WDS