Form 238-7
7/94

RECEIVED
MAY 18 1995
NORTHERN REGION
IDWR

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

POSTED

Use Typewriter or Ball Point Pen

1. DRILLING PERMIT NO. 94 - 95 - N 0004 -000
Other IDWR No.

2. OWNER:
Name Sharon Valek
Address P.O. Box 83
City Harrison State ID Zip 83833

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S

Twp. 47N North ☒ or South ☐
Rge. 3W East ☐ or West ☒
Sec. 29, 1/4 NW 1/4 SE 1/4 (10 acres / 160 acres)
Gov't Lot ____ County KOOTENAI

Address of Well Site 3.4 miles from Kootenai Schl
City
(Give at least name of road + Distance to Road or Landmark)

Lt. ____ Blk. ____ Sub. Name

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
Bentonite	0	85	35sacks	Dry

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s) 160FT
Was drive shoe seal tested? Y ☐ N ☒ How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+1	150	.250	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe ____ Length of Tailpipe ____

9. PERFORATIONS/SCREENS
☒ Perforations Method Knife
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
140	160	1/4"	25	6"	Steel	☒	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
30 ft. below ground Artesian pressure 0 lb.
Depth flow encountered 155 ft. Describe access port or control devices: Cap

NW SE 29 47N 3W

11. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
5EST	100%	280	2hr

Water Temp. Cold Bottom hole temp. Cold
Water Quality test or comments: Clear & Cold

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
8"	0	6	Clay brown		X
	6	85	Basalt broken		X
	85	140	Clay brown		X
	140	155	Sandstone	X	
6"	155	280	Basalt hard	X	

RECEIVED
MAY 15 1995
Department of Water Resources

OFFICE USE ONLY
Inspected by TDK
Twp 47N Rge 03W Sec 29
1/4 SW 1/4 NE 1/4

Completed Depth 265 (Measurable)
Date: Started 3/01/95 Completed 3/07/95

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc. Firm No. 414
Firm Official Tim R Calligares Date 3/07/95
and
Supervisor or Operator Larry Vanderlinden Jr. Date 3/07/95
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES