Form 238-7
6/93

POSTED

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter
or
Ball Point Pen

1. DRILLING PERMIT NO. 94-94-N-31-007
Other IDWR No.

2. OWNER:
Name Robert J. Wilson
Address 715 9th Street
City Clarkston State Wash Zip 99403

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.



T. 42 North ☒ or South ☐
R. 3 East ☐ or West ☒
Sec. 12, 10 acres 1/4 NW 40 acres 1/4 NE 160 acres 1/4
Gov't Lot ____ County ____

Address of Well Site Black Lake Road by Black Lake Resort
(Give at least Direction + Distance to Road or Landmark)

Lot No. ____ Block No. ____ Subd. Name ____

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other ____

5. TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other ____

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
Bentonite	0	26	5½ sks	Pour

Was drive shoe seal tested? Y☐ N☒ How? ____

8. CASING/LINER:

Diameter	From	To	Guage	Casting	Liner	Steel	Plastic	Welded	Threaded
6	+1½	38½	250			☒	☐	☒	☐
						☐	☐	☐	☐
						☐	☐	☐	☐
						☐	☐	☐	☐

Final location of shoes 38½
Top Packer or Headpipe ____ Bottom Tailpipe ____

9. PERFORATIONS/SCREENS
☒ Perforations Method Drilled
☐ Screens Type ____ Material ____

From	To	Slot Size	Number	Diameter	Tele/Pipe Size	Casting	Liner
-170	-190	[illegible]"	30	¼"	4"	☐	☒
-110	-130		45	¼"	4"	☐	☒
						☐	☐
						☐	☐

NWNE 12 47N 3W

10. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Depth	Time
30			2hrs

Temperature of water Cold Was a water analysis done? Yes ☐ No ☒
By whom? ____
Water Quality (odor, etc.) Clear - Cold - No odor
Bottom Hole Temperature ____

11. STATIC WATER LEVEL:
20 ft. below surface Depth artesian flow found ____
Artesian pressure ____ lb. Describe access port ____
Describe Controlling Devices: ____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	GPM	SWL
8	0	26	Grey Clay		
	26	38	Basalt		
6	38	134	Basalt		
	134	160	Grey Clay		
	160	180	Brown Clay and Gravel	30	20
			K-Packer set at 170'		

RECEIVED
JUL 28 1994
NORTHERN REGION
IDWR

Date: Started 6/27/94 Completed 6/28/94

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name All-Ways Drilling Inc Firm No. 510
Firm Official Stanley Wolfe Date 6/28/94
and
Supervisor or Operator Robert J Wilson Date 6/28/94
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES