

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

77568

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat	:	Long
:	:	:

1. WELL TAG NO. D5220

Drilling Permit No: 94-98-N-27
Other IDWR No.

2. OWNER

Name DRW HOMES

Well Number:


755

Address 8413 NORTHVIEW CT

City SPOKANE State WA Zip 99208

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 47 North or South
Rge. 03 East or West
Sec. 12 1/4 NW 1/4 SW 1/4

Gov't Lot County KOOTENAI

Lat: : Long: :

Address of Well Site BLACK LAKE

City HARRISON

(Give at least name of road + Distance to Road or Landmark)

Lt. Blk. Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	18	1/1	Slurry/Granular

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s)

Was drive shoe seal tested? ☐ Y ☐ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	234	.250	STEEL	☒	☐	☒	☐
4	-222	322	.160	PVC	☐	☒	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations Method SKILLSAW

☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
282	322	1/8X6	75	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

180 ft. below ground Artesian pressure lb.

Depth flow encountered ft. Describe access port or

control devices: Bolt on Well Cap

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
15			1 HR

Water Temp. COLD Bottom Hole Temp

Water Quality test or comments: CLEAR

Depth first Water encountered

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	
				Y	N
10	0	18	Clay Tan W/Basalt	☐	☒
8	18	32	Clay Tan W/Basalt	☐	☒
8	32	117	Basalt W/Clay	☐	☒
8	117	229	Clay W/Silt	☐	☐
8	229	234	Basalt Interbeds	☐	☒
5.5	234	283	Basalt Interbeds	☐	☒
5.5	283	322	Basalt W/Fractures	☒	☐
	0	0	bolt on well cap	☐	☐

RECEIVED

SEP 04 1998

NORTHERN REGION
IDWR

Completed Depth 322 (Measurable)
Date: Started 8/20/98 Completed 8/24/98

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official Date 8/24/98

and

Supervisor or Operator Date 8/24/98

(Sign Once if Firm Official and Operator)

(Todd Morgan)

47N 3W 12