

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

WELL OWNER	
Name	Jim Henderson
Address	St. Maries, Idaho 83861
Owner's Permit No.	

NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement

☐ Abandoned (describe method of abandoning)

PROPOSED USE

☐ Domestic	☐ Irrigation	☐ Test	☐ Other (specify type)
☐ Municipal	☐ Industrial	☐ Stock	☐ Waste Disposal or Injection

METHOD DRILLED

☐ Cable ☐ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 300 feet

Casing schedule: ☒ Steel ☐ Concrete

Thickness	Diameter	From	To
<u>350</u> inches	<u>6</u> inches	+ <u>1</u> feet	<u>235</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was casing drive shoe used? ☐ Yes ☐ No

Was a packer or seal used? ☐ Yes ☐ No

Perforated? ☐ Yes ☐ No

How perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation _____ inches by _____ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☐ No

Manufacturer's name _____

Type _____ Model No. _____

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes ☐ No Size of gravel _____

Placed from _____ feet to _____ feet

Surface seal depth _____ Material used in seal ☐ Cement grout

☐ Puddling clay ☐ Well cutting

Sealing procedure used ☐ Slurry pit ☐ Temporary surface casing

☐ Overbore to seal casing

6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name _____

Lot No. _____ Block No. _____

County Benewah County

W 1/2 1/4 SE 1/4 Sec. 20 T. 45 N/S. R. 1 E/W

7. WATER LEVEL

Static water level 150 feet below land surface

Flowing? ☐ Yes ☐ No G.P.M. flow 30

Temperature 50 ° F. Quality 100

Artesian closed-in pressure 100 p.s.i.

Controlled by ☐ Valve ☐ Cap ☐ Plug

[illegible]

9. LITHOLOGIC LOG

[illegible]

10. Work started 11/10/76 finished 11/16/76

II. DRILLERS CERTIFICATION

Firm Name CARMAN DEVELOPMENT CO. Firm No. 228

Address E. 6010 Broadway Date 11/18/76

Signed by (Firm Official) James R. Frank
and
(Operator)