

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Office Use Only			
Inspected by _____			
Twp _____	Rge _____	Sec _____	
Lat: _____	_____	Long: _____	_____

1. WELL TAG NO. D0046337Drilling Permit No: 843913

Other IDWR No. _____

2. OWNER

Name Evans, Scott

Well Number: _____

1260Address 320 Moon Gulch RdCity Kellogg State ID Zip 83837

3. LOCATION OF WELL by legal description

sketch map location must agree with written location

N W E S									

Twp. 48N ☒ North or ☐ South
Rge. 3E ☒ East or ☐ West
Sec. 3 1/4 NE 1/4 SE 1/4
Gov't Lot _____ County SHOSHONE
Lat: _____ Long: _____

Address of Well Site 320 Moon GulchCity Kellogg

(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	18	250 lbs	Overbore

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 50'Was drive shoe seal tested? ☐ Y ☒ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	50	.250	STEEL	☒	☐	☒	☐
4	-8	144	.200	PVC	☐	☒	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations Method _____ Skill Saw☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
128	144	1/8 x 6	50	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

1 ft. below ground Artesian pressure _____ lb.Depth flow encountered 118 ft. Describe access port or control devices: _____

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
8 - 10			1/2 hr

Water Temp. Cold Bottom Hole Temp ColdWater Quality test or comments: ClearDepth first Water encountered 115

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

				Water	
Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Y	N
8	0	3	Top soil	☐	☒
8	3	8	Soil Sand & Gravel	☐	☒
8	8	26	Shale & Gravels	☐	☒
8	26	48	Shale, Gravels & Clay	☐	☒
8	48	50	Gray Shale	☐	☒
6	50	115	Gray Shale	☐	☒
6	115	130	Gray Shale	☒	☐
6	130	144	Gray Shale	☐	☒

RECEIVED

JAN 29 2007

IDWR/North

Completed Depth 144 (Measurable)Date: Started 11/30/2006 Completed 11/30/2006

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448Firm Official [Signature] Date 12-11-06

and

Supervisor or Operator [Signature] Date 11-30-06

Todd Morgan

(Sign Once if Firm Official and Operator)

48N 3E 3

ANDERSON PIN RP48N03E037350

