

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only			
Inspected by _____			
Twp _____	Rge _____	Sec _____	
1/4	1/4	1/4	
Lat: : :	Long: : :		

1. WELL TAG NO. D0056595

DRILLING PERMIT N 854810

Other IDWR No _____

2. OWNER:

Name Joe McCormick

Address 9896 Chelsea Ct

City Hayden State ID Zip 83835

3. LOCATION OF WELL by legal description:

N		Twp	51N	North	☒ or	South	☐
Rge		05W	East	☐ or	West	☒	
Sec		19	1/4	SE	1/4	SE	1/4
Gov't Lot		County		Kootenai			
Lat		47:45:15		Long		117:00:22	
Address of Well Site: (see next line)							

housar lake rd second drive on right City rathdrum

Lot _____ Blk _____ Sub. Name (see next line)

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK	Material	Amount	Method
BENTONITE	0	20	14 SACKS
			DRY POOR

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) 200

Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	+2	200	0.250	STEEL	☒	☐	☒	☐

Length Headpipe N/A Length Tailpipe N/A

9. PERFORATIONS/SCREENS

- ☐ Perforations? Method _____
☐ Screens? Screen Type n/a

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

145 ft. below ground. Artesian pressure 0 lb.
Depth flow encountered 145 ft. Describe access port or control devices: cap welded

11. WELL TESTS:

- ☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
50+	n/a	195	1hr

Water Temp. cold Bottom hole temp. cold
Water Quality test or comments: (below) Depth first Water Encountered 145
clear

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
				Y	N
10	0	20	SAND GRAVEL TOP SOIL	☐	☒
8	20	172	SAND GRAVEL CLAY MIX	☒	☐
8	175	200	SAND GRACEL 3/4	☒	☐

RECEIVED

APR 23 2009

IDWR/North

Completed Dept 200 (Measurable)

Date: Started 2/11/2009 Completed 2/12/2009

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc. Firm No 414

Firm Official Timothy R. Volking Date 2/13/2009

Supervisor or Operator Timothy R. Volking Date 2/13/2009

SIN OSW 19