

RECEIVED

Form 238-7
11/97

JUN 28 1999

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

076498

Office Use Only		
Inspected by _____		
Twp _____	Rge _____	Sec _____
1/4 _____	1/4 _____	1/4 _____
Lat: _____	Long: _____	

IDWR/North

1. WELL TAG NO. D00010172

DRILLING PERMIT N 93-99-N-4

Other IDWR No _____

2. OWNER:

Name Chuck Trimmer

Address 2271 Idaho Road

City Tekoa

State WA

Zip 99033

3. LOCATION OF WELL by legal description:

N	Twp	46N	North	☒ or	South	☐
	Rge	06W	East	☐ or	West	☒
	Sec	24	1/4	SE	1/4	SW
			10 Ac	40 Ac	160 Ac	
Gov't Lot	County <u>Benewah</u>					
Lat	Long					

Address of Well Site: (see next line)

95 S to Plummer, L on A Street to Idaho Road - City

Lot _____ Blk _____ Sub. Name (see next line)

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	80	12 sacks	pour in

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) 192'

Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6"	1	192	0.025	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length Headpipe _____ Length Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations? Method Air perforator

☐ Screens? Screen Type _____

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
-95	-140	1"	800		Steel	☒	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

45 ft. below ground. Artesian pressure _____ lb.

Depth flow encountered 92 ft. Describe access port or

control devices: Steel cap welded

11. WELL TESTS:

- ☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
40-60	100%	190	2 hrs.

Water Temp. _____ cold Bottom hole temp. _____ cold

Water Quality test or comments: (below) Depth first Water Encountered 92
clear, cold, no smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Lithology, Water Quality and Temperature	Water	
				Y	N
8	0	3	Clay - brown	☐	☐
8	3	18	Clay - brown with shale/gravel	☐	☐
8	18	92	Clay - maroon - hard	☐	☐
8	92	94	Shale, clay & sandstone mix - soft	☐	☐
			40-60	☐	☐
8	94	200	Shale/clay/sandstone mix - soft	☐	☐

Completed Depth 192 (Measurable)

Date: Started 6/23/99 Completed 6/24/99

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name 062499 United Drilling Firm No 414

Firm Official Tim N. Williams Date 6/25/99

Supervisor or Operator Jason C. Beckham Date 6/25/99

FORWARD WHITE COPY TO WATER RESOURCES

46 N 6 W 24