

IDAHO DEPARTMENT OF WATER RESOURCES

WELLED DRILLER'S REPORT

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat	:	Long	:

1. WELL TAG NO. D0013339

Drilling Permit No:

Other IDWR No.

2. OWNER

Name Andy Reule

Well Number:

49

Address 73-C Windfall Pass Road


City Plummer

State ID

Zip 83851

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 45



North or



South

Rge. 4



East or



West

Sec. 17



1/4 SE



1/4 SE



1/4

Gov't Lot



County BENEWAH

Lat:



Long:

Address of Well Site



City Plummer

(Give at least name of road + Distance to Road or Landmark)

Lt.

Blk.

Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation

☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
well seal				
BENTONITE	0	18	11 sacks	overbore

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 18

Was drive shoe seal tested? ☐ Y ☐ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
4	-10	265	.160	PVC	☐	☒	☐	☐
6	2	18	.250	steel	☒	☐	☒	☐

Length of Headpipe

Length of Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations Method Skill saw

☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
225	265	1/8x6	100	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

50 ft. below ground Artesian pressure lb.

Depth flow encountered ft. Describe access port or control devices:

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
15			1 hour

Water Temp. cold Bottom Hole Temp. cold

Water Quality test or comments: clear

Depth first Water encountered 142

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

				Water	
Bore	From	To	Remarks: Lithology, Water Quality, Temperature	Y	N
10	0	2	Topsoil	☐	☒
10	2	11	Clay tan w/shale	☐	☒
10	11	18	Shale tan	☐	☒
6	18	47	Shale tan	☐	☒
6	47	142	Shale gray	☐	☒
6	142	147	Shale gray fractured	☒	☐
6	147	238	Shale gray	☐	☒
6	238	265	Shale gray fractured	☒	☐

RECEIVED
OCT 20 2000
Department of Water Resources

Completed Depth 265 (Measurable)
Date: Started 6/29/00 Completed 6/30/00

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official [Signature] Date 7-5-00

and Supervisor or Operator [Signature] Date 7-5-00

(Sign Once, If Firm Official and Operator)
Todd Morgan

45N 4W 17