

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

RECEIVED

076636

Office Use Only
Inspected by _____
Twp _____ Rge _____ Sec _____
1/4 1/4 1/4
Lat : : Long : :

1. WELL TAG NO. D0005906

DRILLING PERMIT N

Other IDWR No 95-99-N-39

2. OWNER:

Name David Stone

Address 1163 Tokay Corn

City Livermore

State CA

Zip 94550

3. LOCATION OF WELL by legal description:

N
Twp 49N North ☒ or South ☐
Rge 04W East ☐ or West ☒
Sec 24 1/4 NE 1/4 NE 1/4
Gov't Lot 10 Ac 40 Ac 160 Ac
Lat _____ County Kootenai
S
Address of Well Site: (see next line)

97 South to Driftwood Dr first drive to right first L City Coeur d' Alene

Lot _____ Blk _____ Sub. Name (see next line)

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	18	16 sacks	pour in

Drive Shoe Used? ☐ Y ☒ N Shoe Depth(s) _____

Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6"	1	143	0.025	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length Headpipe _____ Length Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations? Method _____

☐ Screens? Screen Type _____

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

80 ft. below ground. Artesian pressure _____ lb.

Depth flow encountered 185 ft. Describe access port or

control devices: Steel cap welded

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
45-60 est	100%	130	1 hr

Water Temp. _____ cold Bottom hole temp. _____ cold

Water Quality test or comments: (below) Depth first Water Encountered 185

clear, cold, no smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
				Y	N
8	0	23	Broken basalt - clay	☐	☐
8	23	30	Clay - gray/white	☐	☐
8	3	35	Clay - orange/brown	☐	☐
8	35	60	Basalt - black - medium	☐	☐
8	60	80	Basalt - very broken	☐	☐
8	80	142	Basalt - hard - black	☐	☐
6	142	165	Basalt - black - hart	☐	☐
6	165	185	Clay - brown	☐	☐
6	185	190	Sand - black & white	☐	☐
				☐	☐
			Utilizing natural basalt gravel pack	☐	☐

Completed Depth 180 (Measurable)
Date: Started 4/30/99 Completed 5/3/99

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc.

Firm No 414

Firm Official and

Date 5/4/99

Supervisor or Operator Jason C. Beckham

Date 5/4/99

FORWARD WHITE COPY TO WATER RESOURCES

49N 4W 24