

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

ENTERED

Office Use Only			
Inspected by _____			
Twp _____	Rge _____	Sec _____	
1/4 _____		1/4 _____	
Lat: _____	Long: _____		

1. WELL TAG NO. **D0051674**

DRILLING PERMIT No 845819

Other IDWR No _____

2. OWNER:

Name **Jeremy Tripp**

Address **1601 West Seventh**

City **Coeur d'Alene**

State **ID**

Zip **83814**

3. LOCATION OF WELL by legal description:

N		Twp 53N	North ☒ or South ☐
Rge 03W		East ☐ or West ☒	
Sec 31		1/4 NW 1/4 SW 1/4	
		10 Ac 40 Ac 160 Ac	
Gov't Lot 4		County Kootenai	
Lat 47:72:39		Long 116:75:11	

Address of Well Site: (see next line)

diagonal

City athol

Lot **4** Blk _____ Sub Name (see next line)

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
BENTONITE	0	18	15 SACKS	DRY POOR

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) _____ RING / 360

Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	+1	460	0.250	STEEL	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length Headpipe _____ Length Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations? Method _____

☐ Screens? Screen Type **na**

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

345 ft. below ground Artesian pressure **0** lb

Depth flow encountered **345** ft. Describe access port or

control devices: **cap welded**

11. WELL TESTS

- ☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
6 gpm	100%	360	2hrs

Water Temp _____ cold

Bottom hole temp _____ cold

Water Quality test or comments: (below) Depth first Water Encountered **345**
clear

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
8	0	125	CEMENTED SAND AND GRAVEL	Y	N
8	125	300	CEMENTED GRAVEL WITH BILDERS	☐	☒
8	300	318	BOLDER	☐	☒
8	318	340	GRAY CLAY	☐	☒
8	340	480	HARD BROWN CLAY 6GPM AT 460	☒	☐

RECEIVED

APR 30 2007

IDWR/North

RECEIVED

JUL 23 2007

DEPARTMENT OF
WATER RESOURCES

SCANNED

JUL 11 2007

Completed Dept _____ 460 (Measurable)

Date: Started **3/26/2007** Completed **3/28/2007**

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed

Firm **United Drilling Inc.**

Firm No **414**

Firm Official **Timothy R. Volking**

Date **4/18/2007**

Supervisor or Operator **Timothy R. Volking**

Date **4/18/2007**

53N 3W 31