

RECEIVED

Form 20-7
11/97

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

076752

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat:	:	Long:
:	:	:

IDWR/North

1. WELL TAG NO. D 10607

DRILLING PERMIT NO. 95-99-N-163-200

Other IDWR No. _____

2. OWNER:

Name Alan Mikes

Address 1125 S. Marlam

City Spokane State WA Zip 99206

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N							
W		X		E		S	

Twp. 47 North ☒ or South ☐
 Rge. 5 East ☐ or West ☒
 Sec. 1 1/4 N/E 1/4 S/E 1/4
 Gov't Lot _____ County Kootenai 10 acres
 Lat: _____ Long: _____
 Address of Well Site Cave bay Johnson
 City Waltley
Rd. 8575
 (Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation

☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☐ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK		AMOUNT		METHOD
Material	From	To	Sacks or Pounds	
Bentonite	0	20	200#	Four day

Was drive shoe used? ☒ N. Shoe Depth(s) 20

Was drive shoe seal tested? ☒ Y ☐ N How? As

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2	20	20	Steel	☒	☐	☒	☐
4"	20	300	160	PVC	☐	☒	☐	☐

Length of Headpipe N/A Length of Tailpipe N/A

9. PERFORATIONS/SCREENS

Perforations Method Drill

Screens Screen Type N/A

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
220	260	1/4"	60	4"	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

100 ft. below ground Artesian pressure N/A lb.

Depth flow encountered 102 ft. Describe access port or

control devices: Well cap

11. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
10 gpm			1 hr

Water Temp. Cold Bottom hole temp. Cold

Water Quality test or comments: Clear

Depth first Water Encounter 102

12. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
8"	0	1	Overburden		☒
8"	1	22	Clay brown		☒
6"	22	300	Basalt		☒

Completed Depth 300' (Measurable)

Date: Started 10-6-99 Completed 10-7-99

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Always Drilling, Inc. Firm No. 510

Firm Official Shirley Wolf Date 10-20-99

and

Driller or Operator Waltley Date 10-7-99

(Sign once if Firm Official & Operator)

47N 5W 1 FORWARD WHITE COPY TO WATER RESOURCES