RECEIVED
SEP 06 2002
IDWR/North

Form 238
11/97


IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT
Corrected Report

Office Use Only
Inspected by_____
Twp_____ Rge____ Sec_____
____1/4 ____1/4 ____1/4
Lat: Long:

1. WELL TAG NO. D0022571
DRILLING PERMIT N 782645
Other IDWR No

2. OWNER:
Name Terry Campbell
Address 3825 N Ramsey / Apt 1602
City Coeur d'Alene State ID Zip 83815

3. LOCATION OF WELL by legal description:



Twp 49N North ✔ or South
Rge 03W East or West ✔
Sec 10 ____ 1/4 SW 1/4 SW 1/4
10 Ac 40 Ac 160 Ac
Gov't Lot ____ County Kootenai
Lat ____ Long ____
Address of Well Site: (see next line)
97 to S Caribou Ridge Rd. lot 10 City
Lot ____ Blk ____ Sub. Name (see next line)

4. USE:
✔ Domestic Municipal Monitor Irrigation
Thermal Injection Other

5. TYPE OF WORK check all that apply (Replacement etc.)
✔ New Well Modify Abandonment Other

6. DRILL METHOD
✔ Air Rotary Cable Mud Rotary Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	39	7 Sacks	Pour In

Drive Shoe Used? ✔ Y N Shoe Depth(s) 39
Drive Shoe Seal Tested? Y ✔ N How?

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	1	39	0.250	Steel	✔		✔	
4	4	400	0.160	PVC		✔		

Length Headpipe ____ Length Tailpipe ____

9. PERFORATIONS/SCREENS
Perforations? Method
✔ Screens? Screen Type PVC

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
380	400	.020		4	PVC		✔

10. STATIC WATER LEVEL or ARTESIAN PRESSURE
60 ft. below ground. Artesian pressure ____ lb.
Depth flow encountered 215 ft. Describe access port or control devices Steel Cap Welded

49N 3W 10

11. WELL TESTS:
Pump Bailer ✔ Air Flowing Artesian

Yield gal./min	Drawdown	Pump Level	Time
5	100%	398	1 Hour

POSTED

Water Temp. Cold Bottom hole temp. Cold
Water Quality test or comments: (below) Depth first Water Encountered 215
Clear Cold No Odor

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water Y	Water N
8	0	3	Topsoil		✔
8	3	14	Clay W/Shale Gravel		✔
8	14	34	Shale Dark Brown Soft		✔
8	34	39	Shale Light Brown Medium		✔
8	39	88	Shale Brown Medium		✔
6	88	130	Green Gray Medium		✔
6	130	180	Gray Blue		✔
6	180	215	Blue Gray		✔
6	215	221	Same Soft 3.5 gpm	✔	
6	221	320	Same Medium		✔
6	320	323	Same Soft 1.5 gpm	✔	
6	323	400	Same Medium		✔

Completed Depth 400 (Measurable)
Date: Started 8/7/02 Completed 8/8/02

13. DRILLERS CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc. Firm No 414
Firm Official and [signature] PRES. Date 8/12/02
Supervisor or Operator Jason C. Beckham Date 8/12/02

FORWARD WHITE COPY TO WATER RESOURCES

564