

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Administration within 30 days after the completion or abandonment of the well.

1. WELL OWNER

Name KENNETH A. RENNER
Address ROUTE 2 HARRISON, IDAHO 83833
Owner's Permit No. 94-72-N-15
749231

2. NATURE OF WORK

- ☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning)

3. PROPOSED USE

- ☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal ☐ Industrial ☐ Stock

4. METHOD DRILLED

- ☐ Cable ☒ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 8 inches Total depth 175 feet
Casing schedule: ☒ Steel ☐ Concrete
Thickness Diameter From To
250 inches 6 inches + 1 feet 93 feet
PVC inches 5 inches 93 feet 175 feet
_____ inches _____ inches _____ feet _____ feet
_____ inches _____ inches _____ feet _____ feet
_____ inches _____ inches _____ feet _____ feet

Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☒ Yes ☐ No
How perforated? ☐ Factory ☐ Knife ☐ Torch
Size of perforation 3/16 inches by 3/16 inches DRILLED
Number From To
140 perforations 135 feet 175 feet
_____ perforations _____ feet _____ feet
_____ perforations _____ feet _____ feet


Well screen installed? ☐ Yes ☒ No
Manufacturer's name _____
Type _____ Model No. _____
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes ☒ No Size of gravel _____
Placed from _____ feet to _____ feet

Surface seal? ☒ Yes ☐ No To what depth 18 feet
Material used in seal ☐ Cement grout ☒ Puddling clay

6. LOCATION OF WELL

Sketch map location must agree with written location.



County KOOTENAI
NE 1/4 NE 1/4 Sec. 33 49N 3W
NE SW 33 49N 3W

7. WATER LEVEL

Static water level 5 feet below land surface
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Temperature 60.0° F. Quality Cool
Artesian closed-in pressure _____ p.s.i.
Controlled by ☐ Valve ☐ Cap ☐ Plug

8. WELL TEST DATA

☐ Pump ☐ Bailer ☒ Other AIR
Discharge G.P.M. Draw Down Hours Pumped
60 — 1 1/2

9. LITHOLOGIC LOG

Hole Diam.	Depth		Material	Water	
	From	To		Yes	No
<u>8</u>	<u>0</u>	<u>79</u>	<u>CLAY</u>		☒
	<u>79</u>	<u>175</u>	<u>SERPENTINE</u>	☒	

WATER AT: @ 135
42 GPM @ 155
80 GPM @ 175
60 GPM @ 175

OFFICE USE ONLY

Inspected by ASSESSOR
Two 49N Rgs 3W Sec 33
1/4 NE 1/4 SW 1/4

10.

Work started 12-22-72 finished 12-24-72

11. DRILLER'S CERTIFICATION

This well was drilled under my supervision and this report is true to the best of my knowledge.

ASSOCIATED WELL DRILLERS, INC 245
Driller's or Firm's Name Number
PO BOX 723 COEUR D'ALENE, IDAHO
Address
Signed by E. MULLICK 2-14-73
Date

USE ADDITIONAL SHEETS IF NECESSARY

FORWARD THE WHITE BLUE AND BULK COPIES TO THE DIRECTOR

