

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT 076750

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat	:	:	Long
:	:	:	:

1. WELL TAG NO. D10518

SEP 30 1999

Drilling Permit No: 95-99-N-160

Other IDWR No.

IDWR North

2. OWNER

Well Number:

Name GILMORE, TOM


941

Address 10511 LAKE VIEW DR

City HAYDEN State ID Zip 83835

3. LOCATION OF WELL by legal description

sketch map location must agree with written location

Twp. 50 ☒ North or ☐ SouthRge. 04 ☐ East or ☒ West

Sec. 33 1/4 NE 1/4 SE 1/4

Gov't Lot County KOOTENAI

Lat: : : Long: : :

Address of Well Site MICA FLATS

City CDA

(Give at least name of road + Distance to Road or Landmark)

Lt. Blk. Sub. Name

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	35	13 BAGS	OVERBORE

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 35Was drive shoe seal tested? ☐ Y ☐ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	35	.250	STEEL	☒	☐	☒	☐
4	-8	183	.160	PVC	☐	☒	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

☐ Perforations Method SKILLSAW☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
143	183	1/8X4	170	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

80 ft. below ground Artesian pressure lb.

Depth flow encountered 70 ft. Describe access port or control devices:

11. WELL TESTS:

- ☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
10 GPM		183	1 HR

Water Temp. Bottom Hole Temp

Water Quality test or comments:

Depth first Water encountered 70'

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	
				Y	N
10	0	30	Soil, Clay & Decomposed Granite	☐	☒
10	30	35	Decomposed Granite Brown Soft	☐	☒
6	35	70	Granite Brown White Soft	☐	☒
6	70	75	Granite Black & Copper W/Water App	☒	☐
6	75	170	Granite Black & Copper W/White Med	☐	☒
6	170	174	Granite White Green W/Water Approxi	☒	☐
6	174	183	Granite Black & Copper	☐	☒

Completed Depth 183' (Measurable)

Date: Started 9/17/99 Completed 9/17/99

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official Date 9/17/99

and Supervisor or Operator Date 9/17/99

(Sign Once if Firm Official and Operator)

(Louie Hanner)

50N 4W 33