Form 238-7
7/98
Starships Consulting and Management Services

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Location Corrected by IDWR To:
T54N R04W Sec. 32 SENWSW
By: mciscell 2013-09-25


1. WELL TAG NO. D0054254
Drilling Permit No: 850214
Other IDWR No.

ENTERED

Well Number: 1380

2. OWNER
Name BEDARD, RICHARD
Address BOX 322
City RATHDRUM State ID Zip 83858

3. LOCATION OF WELL by legal description
sketch map location must agree with written location



Twp. 54N ☑ North or ☐ South
Rge. 04W ☐ East or ☑ West
Sec. 32 1/4 SW 1/4 SW 1/4
Gov't Lot ____ County BONNER
Lattitude: N47:58:972 Longitude: W116:52:058

Address of Well Site #21 Old Forest Rd. City SPIRIT LK
(Give at least name of road + Distance to Road or Landmark)
Lt. ____ Blk. ____ Sub. Name ____

4. USE:
☑ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)
☑ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD
☑ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
BENTONITE	0	40	600 LBS	OVERBORE

Was drive shoe used? ☑ Y ☐ N Shoe Depth(s) 600
Was drive shoe seal tested? ☐ Y ☑ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Materi	Casing	Liner	Welded	Threaded
6	+2	600	.250	STEEL	☑	☐	☑	☐

Length of Headpipe ____ Length of Tailpipe ____

9. PERFORATIONS/SCREENS
☐ Perforations Method ____
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
550 ft. below ground Artesian pressure ____ lb.
Depth flow encountered 550 ft. Describe access port or control devices:

54N 4W 32

11. WELL TESTS:
☐ Pump ☐ Bailer ☑ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
15			1 1/4

Water Temp. COLD Bottom Hole Temp COLD
Water Quality test or comments: GOOD
Depth first Water encountered 550

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water Y	Water N
10	0	3	Top Soil	☐	☑
10	3	18	Sand & Gravel 3/4 Minus	☐	☑
8	18	150	Sand & Gravel 3/4 Minus	☐	☑
8	150	160	Sands,Gravels & Small Boulders	☐	☑
8	160	190	Sand & Gravel 3/4 Minus	☐	☑
8	190	300	Sand & Fine Gravels	☐	☑
8	300	550	Sand & Gravel 3/4 Minus	☐	☑
8	550	600	Gravels 3/8" to 1/2" 15 gpm	☑	☐

RECEIVED
JAN 15 2008
IDWR/North

Completed Depth 600 (Measurable)
Date: Started 12/7/2007 Completed 12/14/2007

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H20 WellService, Inc. Firm No. 448
Firm Official ____ Date 1-2-08
and
Supervisor or Operator ____ Date 12/15/2007
Mike Halterman (Sign Once if Firm Offical and Operator)