

WELL DRILLER'S REPORT

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat	:	:	Long
:	:	:	:

1. WELL TAG NO. D0053931

Drilling Permit No:

Other IDWR No.

848542

ENTERED

2. OWNER

Name BUTCH BROWER DELLINGER

Well Number:


1344

Address 26883 D CDA RIVER RD.

City WALLACE State ID Zip 83873

3. LOCATION OF WELL by legal description

sketch map location must agree with written location

Twp. 50N ☒ North or ☐ SouthRge. 4E ☒ East or ☐ West

Sec. 10 1/4 NE 1/4 NW 1/4

Gov't Lot County SHOSHONE

Latitude: N47:41:708 Longitude: W115:56:260

Address of Well Site Same

City PRITCHARD

(Give at least name of road + Distance to Road or Landmark)

Lt. 11 Blk. Sub. Name Copper Home Track

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	18	800 lbs	Temp / Overbore

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 40Was drive shoe seal tested? ☐ Y ☒ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	40	250	STEEL	☒	☐	☒	☐
4	-20	540	.200	PVC	☐	☒	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations Method SKILL SAW☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
520	540	14 X 6	50	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

30 ft. below ground Artesian pressure lb.

Depth flow encountered 495 ft. Describe access port or control devices:

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
10			2 HRS

Water Temp. COLD Bottom Hole Temp. COLD

Water Quality test or comments: Slight Orange

Depth first Water encountered 240

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	Y	N
10	0	6	Top Soil		☐	☒
10	6	18	3/4 Minus Gravels 5gpm		☒	☐
8	18	36	3/4 Minus Gravels		☐	☒
8	36	40	Hard Grey Shale		☐	☒
6	40	240	Hard Grey Shale		☐	☒
6	240	250	Fract. Grev Shale 5 gpm		☒	☐
6	250	360	Hard Grey Shale		☐	☒
6	360	420	Hard Greenish Shale		☐	☒
6	420	490	Hard Grey Shale		☐	☒
6	490	500	Hard Grey Shale w/ Fracts 5gpm		☒	☐
6	500	540	Hard Grey Shale		☐	☒

RECEIVED

AUG 31 2007

IDWR/North

Completed Depth 540 (Measurable)
Date: Started 8/16/2007 Completed 8/20/2007

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official *Mike Halterma* Date 8-27-07Supervisor or Operator *Mike Halterma* Date 8/21/07

MIKE HALTERMA (Sign Once if Firm Official and Operator)

50N 4E 10