

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat	Long	

1. WELL TAG NO. **D0040420**

DRILLING PERMIT N 834440
Other IDWR No _____

2. OWNER:

Name **Dan & Linda Green**
Address / 17272 N Circle Trail
City Rathdrum State ID _____ Zip 83858

3. LOCATION OF WELL by legal description:

N W E S	Twp	52N	North	☒ or	South	☐
	Rge	03W	East	☐ or	West	☒
	Sec	32	1/4 SW 1/4 SW 1/4			
	Gov't Lot	County	Kootenai			
Lat		Long				
Address of Well Site: (see next line)						

Rimrock & Dodd City Hayden
Lot _____ Blk _____ Sub. Name (see next line)

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	20	5 Sacks	Pour In

Drive Shoe Used? ☐ Y ☒ N Shoe Depth(s) _____
Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6"	+2	-110	0.250	Steel	☒	☐	☒	☐
4"	-85	-265	0.200	PVC	☐	☒	☒	☐
					☐	☐	☐	☐

Length Headpipe _____ Length Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations? Method Drilled _____
☐ Screens? Screen Type _____

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
-205	-265	3/8	200	4"	PVC	☐	☒
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

70 ft. below ground. Artesian pressure _____ lb.
Depth flow encountered 150 ft. Describe access port or control devices: Steel Cap Welded

52N 3W 32

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
15	100%	360	1HR

Water Temp. _____ Cold Bottom hole temp. _____ Cold
Water Quality test or comments: (below) Depth first Water Encountered 260
Clear, Cold, No Smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
				Y	N
8	0	20	Clay Brown	☐	☒
8	20	110	Clay Dark Brown	☐	☒
6	110	135	Basalt & Clay Weathered	☐	☒
6	135	260	Basalt	☒	☐
6	260	264	Basalt Weathered	☐	☒
6	264	265	Clay Tan	☐	☒

RECEIVED
JUL 21 2005
IDWR/North

Completed Depth 265 (Measurable)
Date: Started 7/1/05 Completed 7/5/05

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc. Firm No 414
Firm Official [Signature] Date 7/5/05
Supervisor or Operator Curtis S. Hammond Date 7/5/05

SCANNED
NOV 07 2013