Form 238-7
6/93

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT


092192

Use Typewriter or Ball Point Pen

1. DRILLING PERMIT NO. 96-94 - N-56 -
Other IDWR No.

2. OWNER:
Name Michael Deegan
Address P.O.Box 1426
City Priest River State ID Zip 83856

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.



T. 54 North ☒ or South ☐
R. 5 East ☐ or West ☒
Sec. 19 , ____ 10 acres 1/4 SW 40 acres 1/4 NE 160 acres 1/4
Gov't Lot ____ County Bonner

Address of Well Site Stoneridge Terrace
(Give at least Direction + Distance to Road or Landmark)
Lot No. ____ Block No. ____ Subd. Name

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
bentonite				

Was drive shoe seal tested? YES NO How?

8. CASING/LINER:

Diameter	From	To	Guage	Casting	Liner	Steel	Plastic	Welded	Threaded
6	+1	262	250			☒	☐	☒	☐
4	210	400	160			☐	☒	☐	☐
						☐	☐	☐	☐
						☐	☐	☐	☐

Final location of shoes 262 ft
Top Packer or Headpipe Bottom Tailpipe

9. PERFORATIONS/SCREENS
☒ Perforations Method Saw
☐ Screens Type Material

From	To	Slot Size	Number	Diameter	Tele/Pipe Size	Casting	Liner
360	400		38			☐	☒
						☐	☐
						☐	☐
						☐	☐

SW NE 19 54N 5W

10. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Depth	Time
3		400	3hr

Temperature of water ____ Was a water analysis done? Yes ☐ No ☐
By whom?
Water Quality (odor, etc.)
Bottom Hole Temperature

11. STATIC WATER LEVEL:
245 ft. below surface Depth artesian flow found
Artesian pressure ____ lb. Describe access port cap
Describe Controlling Devices:

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	GPM	SWL
8	0	160	sand&pea gravel		
6	160	180	cemented gravel		
	180	255	sand&pea gravel brown clay		
	255	360	grey granite soft		
	360	410	broken salt&pepper granite		

RECEIVED
APR 26 1994
IDWR

RECEIVED
MAY 02 1994
Department of Water Resources

FEB 09 1995

Date: Started 4-4-94 Completed 4-11-94

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Bronson Water Wells Firm No. 360
Firm Official K. D. Bronson Date 4-11-94
and
Supervisor or Operator Date
(Sign once if Firm Official & Operator)

SCANNED JAN 07 2014

FORWARD WHITE COPY TO WATER RESOURCES